

Cummings Elementary School - 2022 Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	735
School Name:	Cummings Elementary School
Building ID #:	21420600

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Main Office 39 at Entrance, Staff Faucet	21420600-001SF	2022-06-02	21420600-001SF22A	2.8	No
Staff Room, Staff Faucet	21420600-002SF	2022-06-02	21420600-002SF22A	1.8	No
Staff Room, Drinking Water Fountain	21420600-003DW	2022-06-02	21420600-003DW22A	8.5	No
Hallway at Staff Room, Drinking Water Fountain	21420600-004DW	2022-06-02	21420600-004DW22A	1.4	No
Music Room, Classroom Faucet	21420600-005CF	2022-06-02	21420600-005CF22A	1.9	No
Music Room, Drinking Water Fountain	21420600-006DW	2022-06-02	21420600-006DW22A	8	No
Classroom 8, Classroom Faucet	21420600-007CF	2022-06-02	21420600-007CF22A	<1	No
Classroom 8, Drinking Water Fountain	21420600-008DW	2022-06-02	21420600-008DW22A	2.6	No
LRC, Drinking Water Fountain	21420600-009DW	2022-06-02	21420600-009DW22A	4.3	No
LRC, Classroom Faucet	21420600-010CF	2022-06-02	21420600-010CF22A	1	No
Reading Room North of Classroom 22, Classroom Faucet	21420600-011CF	2022-06-02	21420600-011CF22A	<1	No
Hallway at Classroom 8, Drinking Water Fountain	21420600-012DW			Broken	
Classroom 7, Classroom Faucet	21420600-013CF	2022-06-02	21420600-013CF22A	3.7	No
Classroom 7, Drinking Water Fountain	21420600-014DW	2022-06-02	21420600-014DW22A	6.4	No
Hallway at Classroom 6, Drinking Water Fountain	21420600-015DW	2022-06-02	21420600-015DW22A	3.5	No
Classroom 6, Classroom Faucet	21420600-016CF	2022-06-02	21420600-016CF22A	2	No
Classroom 6, Drinking Water Fountain	21420600-017DW	2022-06-02	21420600-017DW22A	3	No
Classroom 5, Classroom Faucet	21420600-018CF	2022-06-02	21420600-018CF22A	2.3	No
Classroom 5, Drinking Water Fountain	21420600-019DW	2022-06-02	21420600-019DW22A	8.1	No
Classroom 4, Drinking Water Fountain	21420600-020DW	2022-06-02	21420600-020DW22A	2.6	No
Classroom 4, Classroom Faucet	21420600-021CF	2022-06-02	21420600-021CF22A	3.2	No
Classroom 3, Classroom Faucet	21420600-022CF	2022-06-02	21420600-022CF22A	1.4	No

Classroom 3, Drinking Water Fountain	21420600-023DW	2022-08-11	21420600-023DW22B	4.84	No
Classroom 2, Classroom Faucet	21420600-024CF	2022-06-02	21420600-024CF22A	<1	No
Classroom 2, Drinking Water Fountain	21420600-025DW	2022-06-02	21420600-025DW22A	1.3	No
Classroom 1, Classroom Faucet	21420600-026CF	2022-06-02	21420600-026CF22A	<1	No
Classroom 1, Drinking Water Fountain	21420600-027DW	2022-06-02	21420600-027DW22A	<1	No
Classroom 18, Classroom Faucet	21420600-028CF	2022-06-02	21420600-028CF22A	1.8	No
Hallway at Media Center, Drinking Water Fountain	21420600-029DW	2022-06-02	21420600-029DW22A	1.3	No
Classroom 17, Classroom Faucet	21420600-030CF	2022-06-02	21420600-030CF22A	<1	No
Classroom 17, Drinking Water Fountain	21420600-031DW	2022-06-02	21420600-031DW22A	<1	No
Classroom 16, Classroom Faucet	21420600-032CF	2022-06-02	21420600-032CF22A	1.8	No
Classroom 16, Drinking Water Fountain	21420600-033DW	2022-06-02	21420600-033DW22A	3.1	No
Classroom 15, Classroom Faucet	21420600-034CF	2022-06-02	21420600-034CF22A	2	No
Classroom 15, Drinking Water Fountain	21420600-035DW	2022-06-02	21420600-035DW22A	2.2	No
Hallway at Gym, Drinking Water Fountain	21420600-036DW	2022-06-02	21420600-036DW22A	<1	No
Kitchen, Kitchen Faucet	21420600-037KF	2022-06-02	21420600-037KF22A	<1	No
Gym, Drinking Water Fountain	21420600-038DW	2022-06-02	21420600-038DW22A	6.4	No
Classroom 14, Classroom Faucet	21420600-039CF	2022-06-02	21420600-039CF22A	3.4	No
Classroom 14, Drinking Water Fountain	21420600-040DW	2022-06-02	21420600-040DW22A	1.3	No
Classroom 13, Classroom Faucet	21420600-041CF	2022-06-02	21420600-041CF22A	1.3	No
Classroom 13, Drinking Water Fountain	21420600-042DW	2022-06-02	21420600-042DW22A	<1	No
Classroom 12, Classroom Faucet	21420600-043CF	2022-06-02	21420600-043CF22A	2.8	No
Classroom 12, Drinking Water Fountain	21420600-044DW	2022-06-02	21420600-044DW22A	1	No
Classroom 11, Classroom Faucet	21420600-045CF	2022-06-02	21420600-045CF22A	2.7	No
Classroom 11, Drinking Water Fountain	21420600-046DW	2022-06-02	21420600-046DW22A	1.3	No
Classroom 10, Classroom Faucet	21420600-047CF	2022-06-02	21420600-047CF22A	1.6	No
Classroom 10, Drinking Water Fountain	21420600-048DW	2022-06-02	21420600-048DW22A	1.5	No