

Forest Ridge Elementary School Childcare Fixtures - Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	3529
School Name:	Forest Ridge Childcare Facility
Building ID #:	21425700

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Cafeteria restroom, Left Drinking Water Fountain	21425700-001DW	2022-05-25	21425700-001DW22A	<1	No
Cafeteria restroom, Right Drinking Water Fountain	21425700-002DW	2022-05-25	21425700-002DW22A	<1	No
Cafeteria, North Storage Area, Staff Faucet	21425700-003SF	2022-05-25	21425700-003SF22A	<1	No
Gym, North Wall, Drinking Water Fountain	21425700-004DW	2022-05-25	21425700-004DW22A	<1	No