

Gubser Elementary School - 2022 Lead in Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	745
School Name:	Gubser Elementary School
Building ID #:	21421400

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Main Office, Health Room Staff Faucet	21421400-001SF	2022-06-09	21421400-001SF22A	2.9	No
Hallway at Staff Workroom, Drinking Water Fountain	21421400-002DW	2022-06-09	21421400-002DW22A	1.2	No
Classroom A6, Classroom Faucet (Shared sink with drinking water fountain)	21421400-003CF	2022-06-09	21421400-003CF22A	<1	No
Classroom A6, Drinking Water Fountain	21421400-004DW	2022-06-09	21421400-004DW22A	1.1	No
Classroom A5, Classroom Faucet (Shared sink with drinking water fountain)	21421400-005CF	2022-06-09	21421400-005CF22A	6.6	No
Classroom A5, Drinking Water Fountain	21421400-006DW	2022-06-09	21421400-006DW22A	<1	No
Classroom A4, Classroom Faucet	21421400-007CF	2022-06-09	21421400-007CF22A	<1	No
Classroom A4, Drinking Water Fountain	21421400-008DW	2022-06-09	21421400-008DW22A	<1	No
Classroom A3, Classroom Faucet	21421400-009CF	2022-06-09	21421400-009CF22A	2.2	No
Classroom A3, Drinking Water Fountain	21421400-010DW	2022-06-09	21421400-010DW22A	1.5	No
Classroom A2, Classroom Faucet	21421400-011CF	2022-06-09	21421400-011CF22A	2.2	No
Classroom A2, Drinking Water Fountain	21421400-012DW	2022-06-09	21421400-012DW22A	1.5	No
Classroom A1, Classroom Faucet	21421400-013CF	2022-06-09	21421400-013CF22A	2	No
Classroom A1, Drinking Water Fountain	21421400-014DW	2022-06-09	21421400-014DW22A	<1	No
Hallway at Classroom A8, Drinking Water Fountain	21421400-015DW	2022-06-09	21421400-015DW22A	<1	No
Classroom A8, Classroom Faucet	21421400-016CF	2022-06-09	21421400-016CF22A	5.2	No
Hallway at Gym, Drinking Water Fountain	21421400-017DW	2022-06-09	21421400-017DW22A	<1	No
Gym, Drinking Water Fountain	21421400-018DW	2022-06-09	21421400-018DW22A	<1	No
Cafeteria, Left Drinking Water Fountain	21421400-019DW	2022-06-09	21421400-019DW22A	<1	No
Cafeteria, Right Drinking Water Fountain	21421400-020DW	2022-06-09	21421400-020DW22A	<1	No
Cafeteria, Water Bottle Filler	21421400-021WB	2022-06-09	21421400-021WB22A	<1	No
Kitchen, Center Island Kitchen Faucet	21421400-022KF	2022-06-09	21421400-022KF22A	<1	No

Kitchen, West Counter across from Storage, Kitchen Faucet	21421400-023KF	2022-06-09	21421400-023KF22A	<1	No
Kitchen, Northwest Corner, Left Kitchen Faucet	21421400-024KF	2022-06-09	21421400-024KF22A	<1	No
Kitchen, Northwest Corner, Right Kitchen Faucet	21421400-025KF	2022-06-09	21421400-025KF22A	<1	No
Kitchen, North Center Counter, Kitchen Faucet	21421400-026KF	2022-06-09	21421400-026KF22A	<1	No
Staff Lounge/Art Room, South Counter Staff Faucet	21421400-027SF	2022-06-09	21421400-027SF22A	<1	No
Staff Lounge/Art Room, East Counter Staff Faucet	21421400-028SF	2022-06-09	21421400-028SF22A	5.3	No
Music Room, Classroom Faucet	21421400-029CF	2022-06-09	21421400-029CF22A	2.5	No
Music Room, Drinking Water Fountain	21421400-030DW	2022-06-09	21421400-030DW22A	<1	No
Hallway at Copy Room, Drinking Water Fountain	21421400-031DW	2022-06-09	21421400-031DW22A	<1	No
Classroom C6, Classroom Faucet	21421400-032CF	2022-06-09	21421400-032CF22A	5.5	No
Classroom C6, Drinking Water Fountain	21421400-033DW	2022-06-09	21421400-033DW22A	2.6	No
Classroom C5, Classroom Faucet	21421400-034CF	2022-06-09	21421400-034CF22A	1.2	No
Classroom C5, Drinking Water Fountain	21421400-035DW	2022-06-09	21421400-035DW22A	<1	No
Classroom C4, Classroom Faucet	21421400-036CF	2022-06-09	21421400-036CF22A	3.3	No
Classroom C4, Drinking Water Fountain	21421400-037DW	2022-06-09	21421400-037DW22A	1.3	No
Classroom C3, Classroom Faucet	21421400-038CF	2022-06-09	21421400-038CF22A	1.7	No
Classroom C3, Drinking Water Fountain	21421400-039DW	2022-06-09	21421400-039DW22A	<1	No
Classroom C2, Classroom Faucet	21421400-040CF	2022-06-09	21421400-040CF22A	2.4	No
Classroom C2, Drinking Water Fountain	21421400-041DW	2022-06-09	21421400-041DW22A	<1	No
Classroom C1, Classroom Faucet	21421400-042CF	2022-06-09	21421400-042CF22A	2.3	No
Classroom C1, Drinking Water Fountain	21421400-043DW	2022-06-09	21421400-043DW22A	1.4	No
Hallway between B Pod and D Pod, Drinking Water Fountain	21421400-044DW	2022-06-09	21421400-044DW22A	<1	No
Classroom D4, Classroom Faucet	21421400-045CF	2022-06-09	21421400-045CF22A	<1	No
Classroom D4, Drinking Water Fountain	21421400-046DW	2022-06-09	21421400-046DW22A	<1	No
Classroom D3, Classroom Faucet	21421400-047CF	2022-06-09	21421400-047CF22A	<1	No
Classroom D3, Drinking Water Fountain	21421400-048DW	2022-06-09	21421400-048DW22A	<1	No
Classroom D2, Classroom Faucet	21421400-049CF	2022-06-09	21421400-049CF22A	<1	No
Classroom D2, Drinking Water Fountain	21421400-050DW	2022-06-09	21421400-050DW22A	<1	No
Classroom D1, Classroom Faucet	21421400-051CF	2022-06-09	21421400-051CF22A	<1	No
Classroom D1, Drinking Water Fountain	21421400-052DW	2022-06-09	21421400-052DW22A	<1	No
Classroom B6, Classroom Faucet	21421400-053CF	2022-06-09	21421400-053CF22A	5.2	No
Classroom B6, Drinking Water Fountain	21421400-054DW	2022-06-09	21421400-054DW22A	<1	No
Classroom B5, Classroom Faucet	21421400-055CF	2022-06-09	21421400-055CF22A	1.8	No

Classroom B5, Drinking Water Fountain	21421400-056DW	2022-06-09	21421400-056DW22A	<1	No
Classroom B4, Classroom Faucet	21421400-057CF	2022-06-09	21421400-057CF22A	3.2	No
Classroom B4, Drinking Water Fountain	21421400-058DW	2022-06-09	21421400-058DW22A	1.2	No
Classroom B3, Classroom Faucet	21421400-059CF	2022-06-09	21421400-059CF22A	<1	No
Classroom B3, Drinking Water Fountain	21421400-060DW	2022-06-09	21421400-060DW22A	1.3	No
Classroom B2, Classroom Faucet	21421400-061CF	2022-06-09	21421400-061CF22A	3.5	No
Classroom B2, Drinking Water Fountain	21421400-062DW	2022-06-09	21421400-062DW22A	1.5	No
Classroom B1, Classroom Faucet	21421400-063CF	2022-06-09	21421400-063CF22A	4.2	No
Classroom B1, Drinking Water Fountain	21421400-064DW	2022-06-09	21421400-064DW22A	1.6	No
Support Center, Classroom Faucet	21421400-065CF	2022-06-09	21421400-065CF22A	2.7	No