

Hammond Elementary School - 2022 Lead in Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	3376
School Name:	Hammond Elementary School
Building ID #:	21425200

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Left drinking water fountain, at gym restrooms	21425200-001DW	2022-06-03	21425200-001DW22A	<1	No
Right drinking water fountain, at gym restrooms	21425200-002DW	2022-06-03	21425200-002DW22A	2.4	No
Kitchenette sink, at north end of multipurpose room	21425200-003KF	2022-06-03	21425200-003KF22A	<1	No
Kitchen sink, north side of peninsula	21425200-004KF	2022-06-03	21425200-004KF22A	<1	No
Right drinking water fountain, at north end of gym	21425200-005DW	2022-06-03	21425200-005DW22A	<1	No
Music room, drinking water fountain	21425200-006DW	2022-06-03	21425200-006DW22A	1.6	No
Music room, class sink faucet	21425200-007CF	2022-06-03	21425200-007CF22A	<1	No
Nurses office, drinking water fountain	21425200-008DW	2022-06-03	21425200-008DW22A	<1	No
Nurses office, staff faucet	21425200-009SF	2022-06-03	21425200-009SF22A	<1	No
Drinking water fountain, file room	21425200-010DW	2022-06-03	21425200-010DW22A	2.1	No
Staff sink faucet, file room	21425200-011SF	2022-06-03	21425200-011SF22A	<1	No
Staff room, sink faucet	21425200-012SF	2022-06-03	21425200-012SF22A	<1	No
Classroom A7, drinking water fountain	21425200-013DW	2022-06-03	21425200-013DW22A	1.4	No
Classroom A7, class sink faucet	21425200-014CF	2022-06-03	21425200-014CF22A	<1	No
Classroom A6, drinking water fountain	21425200-015DW	2022-06-03	21425200-015DW22A	<1	No
Classroom A6, class sink faucet	21425200-016SF	2022-06-03	21425200-016SF22A	<1	No
Classroom A5, drinking water fountain	21425200-017DW	2022-06-03	21425200-017DW22A	<1	No
Classroom A5, class sink faucet	21425200-018CF	2022-06-03	21425200-018CF22A	<1	No
Classroom A4, drinking water fountain	21425200-019DW	2022-06-03	21425200-019DW22A	<1	No
Classroom A4, class sink faucet	21425200-020CF	2022-06-03	21425200-020CF22A	<1	No
Classroom A3, drinking water fountain	21425200-021DW	2022-06-03	21425200-021DW22A	1.4	No
Classroom A3, class sink faucet	21425200-022CF	2022-06-03	21425200-022CF22A	<1	No
Classroom A2, drinking water fountain	21425200-023DW	2022-06-03	21425200-023DW22A	<1	No

Classroom A2, class sink faucet	21425200-024CF	2022-06-03	21425200-024CF22A	<1	No
Classroom A1 LRC, drinking water fountain	21425200-025DW	2022-06-03	21425200-025DW22A	2.5	No
Classroom A1 LRC, class sink faucet	21425200-026CF	2022-06-03	21425200-026CF22A	<1	No
Media center / library, NE corner staff sink faucet	21425200-027SF	2022-06-03	21425200-027SF22A	1.1	No
Classroom C6, drinking water fountain	21425200-028DW	2022-06-03	21425200-028DW22A	<1	No
Classroom C6, class sink faucet	21425200-029CF	2022-06-03	21425200-029CF22A	<1	No
Classroom C5, drinking water fountain	21425200-030DW	2022-06-03	21425200-030DW22A	<1	No
Classroom C5, class sink faucet	21425200-031CF	2022-06-03	21425200-031CF22A	<1	No
Classroom C4, drinking water fountain	21425200-032DW	2022-06-03	21425200-032DW22A	<1	No
Classroom C4, class sink faucet	21425200-033CF	2022-06-03	21425200-033CF22A	<1	No
Classroom C3, drinking water fountain	21425200-034DW	2022-06-03	21425200-034DW22A	<1	No
Classroom C3, class sink faucet	21425200-035CF	2022-06-03	21425200-035CF22A	<1	No
Classroom C2	21425200-036DW	2022-06-03	21425200-036DW22A	<1	No
Classroom C2, class sink faucet	21425200-037CF	2022-06-03	21425200-037CF22A	<1	No
Classroom C1, drinking water fountain	21425200-038DW	2022-06-03	21425200-038DW22A	<1	No
Classroom C1, class sink faucet	21425200-039CF	2022-06-03	21425200-039CF22A	<1	No
Classroom B6, drinking water fountain	21425200-040DW	2022-06-03	21425200-040DW22A	<1	No
Classroom B6, class sink faucet	21425200-041CF	2022-06-03	21425200-041CF22A	<1	No
Classroom B5, drinking water fountain	21425200-042DW	2022-06-03	21425200-042DW22A	<1	No
Classroom B5, class sink faucet	21425200-043CF	2022-06-03	21425200-043CF22A	<1	No
Classroom B4, drinking water fountain	21425200-044DW	2022-06-03	21425200-044DW22A	<1	No
Classroom B4, class sink faucet	21425200-045CF	2022-06-03	21425200-045CF22A	<1	No
Classroom B3, drinking water fountain	21425200-046DW	2022-06-03	21425200-046DW22A	<1	No
Classroom B3, class sink faucet	21425200-047CF	2022-06-03	21425200-047CF22A	<1	No
Classroom B2, drinking water fountain	21425200-048DW	2022-06-03	21425200-048DW22A	<1	No
Classroom B2, class sink faucet	21425200-049CF	2022-06-03	21425200-049CF22A	<1	No
Classroom B1, drinking water fountain	21425200-050DW	2022-06-03	21425200-050DW22A	<1	No
Classroom B1, class sink faucet	21425200-051CF	2022-06-03	21425200-051CF22A	<1	No

Hammond Elementary School - Portable 1 - 2022 Lead in Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	3376
School Name:	Hammond Elementary School
Building ID #:	21425201

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Classroom N8, class sink faucet	21425201-001CF	2022-06-03	21425201-001CF22A	<1	No
Classroom N8, drinking water fountain	21425201-002DW	2022-06-03	21425201-002DW22A	<1	No
Classroom N9, class sink faucet	21425201-003CF	2022-06-03	21425201-003CF22A	<1	No
Classroom N9, drinking water fountain	21425201-004DW	2022-06-03	21425201-004DW22A	<1	No

Hammond Elementary School - Portable 2 - 2022 Lead in Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	3376
School Name:	Hammond Elementary School
Building ID #:	21425202

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Classroom D2, class sink faucet	21425202-001CF	2022-06-03	21425202-001CF22A	2.7	No
Classroom D2, drinking water fountain	21425202-002DW	2022-06-03	21425202-002DW22A	<1	No
Classroom D1, class sink faucet	21425202-003CF	2022-06-03	21425202-003CF22A	1.7	No
Classroom D1, drinking water fountain	21425202-004DW	2022-06-03	21425202-004DW22A	<1	No