

Hoover Elementary School - 2021 Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	N/A
School Name:	Hoover Elementary School
Building ID #:	21421300

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Health Room	21421300-001-NS	2021-06-24	6242021-21421300-001-NS	<1	No
Room 1	21421300-002-DW	2021-06-24	6242021-21421300-002-DW	2.78	No
Room 1	21421300-003-CF	2021-06-24	6242021-21421300-003-CF	2.87	No
Kitchen	21421300-004-KF	2021-06-24	6242021-21421300-004-KF	<1	No
Kitchen - Dishwashing	21421300-005-KF	2021-06-24	6242021-21421300-005-KF	2.29	No
Room 19	21421300-006-DW	2022-01-28	1282022-21421300-006-DW	2.5	No
Room 19	21421300-007-CF	2021-06-24	6242021-21421300-007-CF	9.03	No
Room 18	21421300-008-DW	2021-06-24	6242021-21421300-008-DW	2.6	No
Room 18	21421300-009-CF	2021-06-24	6242021-21421300-009-CF	1.77	No
Room 17	21421300-010-DW	2021-06-24	6242021-21421300-010-DW	<1	No
Room 17	21421300-011-CF	2021-06-24	6242021-21421300-011-CF	3.02	No
Room 2	21421300-012-DW	2021-06-24	6242021-21421300-012-DW	1.86	No
Room 2	21421300-013-CF	2021-06-24	6242021-21421300-013-CF	1.15	No
Staff Room	21421300-014-SF	2021-06-24	6242021-21421300-014-SF	4.65	No
Main Hallway at Room 3	21421300-015-DW	2022-01-28	1282022-21421300-015-DW	<1	No
Library	21421300-016-CF	2021-06-24	6242021-21421300-016-CF	4.08	No
Library Hallway	21421300-017-DW	2021-06-24	6242021-21421300-017-DW	1.07	No
Library Hallway	21421300-018-DW	2021-06-24	6242021-21421300-018-DW	<1	No
Room 16	21421300-019-DW	2021-06-24	6242021-21421300-019-DW	5.24	No
Room 16	21421300-020-CF	2021-06-24	6242021-21421300-020-CF	3.44	No
Room 15	21421300-021-DW	2021-06-24	6242021-21421300-021-DW	3.74	No
Room 15	21421300-022-CF	2021-06-24	6242021-21421300-022-CF	6.99	No
Room 14	21421300-023-DW	2021-06-24	6242021-21421300-023-DW	5.24	No
Room 14	21421300-024-CF	2021-06-24	6242021-21421300-024-CF	6.75	No
Room 3	21421300-025-DW	2021-06-24	6242021-21421300-025-DW	8.82	No
Room 3	21421300-026-CF	2021-06-24	6242021-21421300-026-CF	<1	No

Room 13	21421300-027-DW	2021-06-24	6242021-21421300-027-DW	8.29	No
Room 13	21421300-028-CF	2021-06-24	6242021-21421300-028-CF	3.8	No
Room 4	21421300-029-DW	2021-06-24	6242021-21421300-029-DW	<1	No
Room 4	21421300-030-CF	2021-06-24	6242021-21421300-030-CF	5.46	No
Room 12	21421300-031-DW	2021-06-24	6242021-21421300-031-DW	9.27	No
Room 12	21421300-032-CF	2021-06-24	6242021-21421300-032-CF	2.32	No
Room 5	21421300-033-DW	2021-06-24	6242021-21421300-033-DW	<1	No
Room 5	21421300-034-CF	2021-06-24	6242021-21421300-034-CF	3.97	No
Room 11	21421300-035-DW	2021-06-24	6242021-21421300-035-DW	14	No
Room 11	21421300-036-CF	2021-06-24	6242021-21421300-036-CF	5.43	No
Room 6	21421300-037-DW	2021-06-24	6242021-21421300-037-DW	18.2	Yes
Room 6 - Resample	21421300-037-DW	2022-02-16	2162022-21421300-037-DW	3.3	No
Room 6	21421300-038-CF	2021-06-24	6242021-21421300-038-CF	2.36	No
Room 10	21421300-039-DW	2021-06-24	6242021-21421300-039-DW	19.4	Yes
Room 10 - Resample	21421300-039-DW	2022-02-16	2162022-21421300-039-DW	1.4	No
Room 10	21421300-040-CF	2021-06-24	6242021-21421300-040-CF	2.16	No
Room 7	21421300-041-DW	2021-06-24	6242021-21421300-041-DW	11.7	No
Room 7	21421300-042-CF	2021-06-24	6242021-21421300-042-CF	9.6	No
Room 8	21421300-043-DW	2021-06-24	6242021-21421300-043-DW	7.32	No
Room 8	21421300-044-CF	2021-06-24	6242021-21421300-044-CF	3.01	No
Room 9	21421300-045-DW	2021-06-24	6242021-21421300-045-DW	2.35	No
Room 9	21421300-046-CF	2021-06-24	6242021-21421300-046-CF	2.18	No
Room 20	21421300-047-DW	2021-06-24	6242021-21421300-047-DW	<1	No
Room 20	21421300-048-CF	2021-06-24	6242021-21421300-048-CF	<1	No
Room 21	21421300-049-DW	2021-06-24	6242021-21421300-049-DW	<1	No
Room 21	21421300-050-CF	2021-06-24	6242021-21421300-050-CF	<1	No
Room 22	21421300-051-DW	2021-06-24	6242021-21421300-051-DW	<1	No
Room 22	21421300-052-CF	2021-06-24	6242021-21421300-052-CF	<1	No
Room 23	21421300-053-DW	2021-06-24	6242021-21421300-053-DW	<1	No
Room 23	21421300-054-CF	2021-06-24	6242021-21421300-054-CF	<1	No
Gymnasium	21421300-055-DW	2021-06-24	6242021-21421300-055-DW	<1	No
Music Room	21421300-056-CF	2021-06-24	6242021-21421300-056-CF	1	No
Cafeteria Hallway	21421300-057-DW	2022-01-28	1282022-21421300-057-DW	4.4	No

Notes:

Fixtures that test above 15 ppb during the initial sampling event are taken out of service, repaired/replaced and then retested prior to returning to service.