

Jane Goodall Environmental Middle School, June 17, 2021

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	N/A
School Name:	JGEMS
Building ID #:	21425900

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Classroom 2	21425900-001-DW	2021-06-17	6172021-21425900-001-DW	6.72	No
Classroom 2	21425900-002-CF	2021-06-17	6172021-21425900-002-CF	7.75	No
Classroom 1	21425900-003-DW	2021-06-17	6172021-21425900-003-DW	14.2	No
Classroom 1	21425900-004-CF	2021-06-17	6172021-21425900-004-CF	11.2	No