

Judson Middle School - 2021 Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	N/A
School Name:	Judson Middle School
Building ID #:	21423200

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Nurse's Office	21423200-001-NS	2021-05-07	572021-21423200-001-NS	1.3	No
Conference Room	21423200-002-SF	2021-05-07	572021-21423200-002-SF	2.3	No
Staff Room	21423200-003-SF	2021-05-07	572021-21423200-003-SF	<1	No
Room 102	21423200-004-CF	2021-05-07	572021-21423200-004-CF	<1	No
Room 102	21423200-005-DW	2021-05-07	572021-21423200-005-DW	<1	No
Room 105	21423200-006-CF	2021-05-07	572021-21423200-006-CF	12.4	No
Room 105	21423200-007-DW	2021-05-07	572021-21423200-007-DW	<1	No
Lobby	21423200-008-DW	2021-05-07	572021-21423200-008-DW	1.2	No
Southwest Hall	21423200-009-DW	2021-05-07	572021-21423200-009-DW	2.4	No
Food Service Prep	21423200-010-KF	2021-05-07	572021-21423200-010-KF	1	No
Food Service Produce	21423200-011-KF	2021-05-07	572021-21423200-011-KF	<1	No
Food Service Ice Machine	21423200-012-IM	2021-05-07	572021-21423200-012-IM	<1	No
Food Service Dishwashing	21423200-013-KF	2021-05-07	572021-21423200-013-KF	<1	No
Commons Low Drinking Fountain	21423200-014-DW	2021-05-07	572021-21423200-014-DW	<1	No
Commons High Drinking Fountain	21423200-015-DW	2021-05-07	572021-21423200-015-DW	<1	No
Commons Bottle Filler	21423200-016-WB	2021-05-07	572021-21423200-016-WB	<1	No
West Gym Entrance Fountain	21423200-017-DW	2021-11-10	11102021-21423200-017-DW	1.3	No
East Gym Entrance Fountain	21423200-018-DW	2021-11-10	11102021-21423200-018-DW	<1	No
Girls Locker Room Fountain	21423200-019-DW	2022-02-01	212022-21423200-019-DW	3.9	No
Gym Northwest Drinking Fountain	21423200-020-DW	2021-05-07	572021-21423200-020-DW	2.8	No
Gym Southeast Drinking Fountain	21423200-021-DW	2021-05-07	572021-21423200-021-DW	<1	No
Boys Locker Room Drinking Fountain	21423200-022-DW	2021-05-07	572021-21423200-022-DW	2.6	No
South Hall Near Restroom Drinking Fountain	21423200-023-DW	2021-05-07	572021-21423200-023-DW	<1	No
South Hall Near Restroom Bottle Filler	21423200-024-WB	2021-05-07	572021-21423200-024-WB	<1	No
Room 502	21423200-025-CF	2021-05-07	572021-21423200-025-CF	<1	No
Room 502	21423200-026-DW	2021-05-07	572021-21423200-026-DW	<1	No

Room 501	21423200-027-CF	2021-05-07	572021-21423200-027-CF	<1	No
Room 501	21423200-028-DW	2021-05-07	572021-21423200-028-DW	<1	No
Room 503	21423200-029-CF	2021-05-07	572021-21423200-029-CF	1	No
Room 503	21423200-030-DW	2021-05-07	572021-21423200-030-DW	<1	No
Room 506A	21423200-031-SF	2021-05-07	572021-21423200-031-SF	<1	No
Room 505A	21423200-032-SF	2021-05-07	572021-21423200-032-SF	<1	No
Music Storage 304	21423200-033-SF	2021-05-07	572021-21423200-033-SF	1.8	No
300 Hallway South	21423200-034-DW	2021-05-07	572021-21423200-034-DW	<1	No
Room 308	21423200-035-CF	2021-05-07	572021-21423200-035-CF	1.4	No
Room 308	21423200-036-DW	2022-02-04	242022-21423200-036-DW	1.4	No
Room 310	21423200-037-CF	2021-05-07	572021-21423200-037-CF	2.1	No
Room 310	21423200-038-DW	2021-05-07	572021-21423200-038-DW	5.5	No
Room 303	21423200-039-DW	2021-05-07	572021-21423200-039-DW	2.3	No
Room 312	21423200-040-CF	2021-05-07	572021-21423200-040-CF	2	No
Room 312	21423200-041-DW	2021-05-07	572021-21423200-041-DW	5.4	No
300 Hallway North	21423200-042-DW	2021-11-10	11102021-21423200-042-DW	<1	No
Room 309 - Kitchen 1	21423200-043-CF	2021-05-07	572021-21423200-043-CF	5	No
Room 309 - Kitchen 2	21423200-044-CF	2021-05-07	572021-21423200-044-CF	1.6	No
Room 309 - Kitchen 3	21423200-045-CF	2021-05-07	572021-21423200-045-CF	1.8	No
Room 309 - Kitchen 4	21423200-046-CF	2021-05-07	572021-21423200-046-CF	1.2	No
Room 309 - Kitchen 5	21423200-047-CF	2021-05-07	572021-21423200-047-CF	<1	No
Room 309 - Kitchen 6	21423200-048-CF	2021-05-07	572021-21423200-048-CF	1.1	No
Room 309 - Teacher Kitchen	21423200-049-CF	2021-05-07	572021-21423200-049-CF	3.6	No
Room 410	21423200-050-CF	2021-05-07	572021-21423200-050-CF	1.6	No
Room 410	21423200-051-DW	2021-05-07	572021-21423200-051-DW	5.9	No
200 Hall North	21423200-052-DW	2021-05-07	572021-21423200-052-DW	5.3	No
200 Hall South	21423200-053-DW	2021-05-07	572021-21423200-053-DW	<1	No
Room 408 - Wood Shop	21423200-054-DW	2021-05-07	572021-21423200-054-DW	1.8	No
100 Hall North	21423200-055-DW	2021-11-10	11102021-21423200-055-DW	<1	No
Room 114	21423200-056-CF	2021-05-07	572021-21423200-056-CF	1.4	No
Room 114	21423200-057-DW	2021-05-07	572021-21423200-057-DW	1	No
Room 112	21423200-058-CF	2021-05-07	572021-21423200-058-CF	6.5	No
Room 110	21423200-059-CF	2021-05-07	572021-21423200-059-CF	2.8	No
Room 108	21423200-060-CF	2021-05-07	572021-21423200-060-CF	4.8	No
Room 108	21423200-061-SF	2021-05-07	572021-21423200-061-SF	<1	No
Aux Gym Lobby Upper Fountain	21423200-062-DW	2021-05-07	572021-21423200-062-DW	<1	No
Aux Gym Lobby Lower Fountain	21423200-063-DW	2021-05-07	572021-21423200-063-DW	<1	No
Aux Gym Bottle Filler	21423200-064-WB	2021-05-07	572021-21423200-064-WB	<1	No
Music Room 501	21423200-065-DW	2021-05-07	572021-21423200-065-DW	2.1	No