

Liberty Elementary School Childcare Fixtures - Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	749
School Name:	Liberty Childcare Facility
Building ID #:	21421700

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Left Drinking Water Fountain in Hallway Outside Restrooms and Adjacent to Cafeteria	21421700-001DW	2022-05-27	21421700-001DW22A	1.7	No
Right Drinking Water Fountain in Hallway Outside Restrooms and Adjacent to Cafeteria	21421700-002DW	2022-05-27	21421700-002DW22A	<1	No