

## McKay High School - 2022 Lead in Drinking Water Sampling Results

<b>Inst. Name:</b>	Salem-Keizer Public Schools
<b>Inst. ID #:</b>	771
<b>School Name:</b>	McKay High School
<b>Building ID #:</b>	21423800

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Classroom 104, Classroom Faucet	21423800-001CF	2022-06-01	21423800-001CF22A	1.9	No
Classroom 108, Classroom Faucet	21423800-002CF	2022-06-01	21423800-002CF22A	<1	No
Classroom 108, Drinking Water Fountain	21423800-003DW	2022-06-01	21423800-003DW22A	<1	No
Classroom 109, East Wall, Northernmost Classroom Faucet (Station 1)	21423800-004CF	2022-06-01	21423800-004CF22A	<1	No
Classroom 109, East Wall, Center Classroom Faucet (Station 2)	21423800-005CF	2022-06-01	21423800-005CF22A	1.6	No
Classroom 109, East Wall, Southernmost Classroom Faucet (Station 3)	21423800-006CF	2022-06-01	21423800-006CF22A	<1	No
Classroom 109, West Wall, Southernmost Classroom Faucet (Station 6)	21423800-007CF	2022-08-11	21423800-007CF22B	10.2	No
Classroom 109, West Wall, Center Classroom Faucet (Station 5)	21423800-008CF	2022-06-01	21423800-008CF22A	<1	No
Classroom 109, West Wall, Northernmost Classroom Faucet (Station 4)	21423800-009CF	2022-06-01	21423800-009CF22A	<1	No
Classroom 109 Culinary Storage Room, Classroom Faucet	21423800-010CF	2022-06-01	21423800-010CF22A	<1	No
Classroom 110, Classroom Faucet	21423800-011CF	2022-06-01	21423800-011CF22A	1.2	No
Classroom 110, Drinking Water Fountain	21423800-012DW	2022-06-01	21423800-012DW22A	3.6	No
Hallway at Classroom 112, Left Drinking Water Fountain	21423800-013DW	2022-06-01	21423800-013DW22A	<1	No
Hallway at Classroom 112, Center Spit Fountain	21423800-014OT	2022-06-01	21423800-014OT22A	<1	No
Hallway at Classroom 112, Right Drinking Water Fountain	21423800-015DW	2022-06-01	21423800-015DW22A	<1	No
Library Work Station, Staff Faucet	21423800-016SF	2022-06-01	21423800-016SF22A	<1	No
Hallway at Classroom 349, Left Drinking Water Fountain	21423800-017DW	2022-06-01	21423800-017DW22A	<1	No
Hallway at Classroom 349, Right Drinking Water Fountain	21423800-018DW	2022-06-01	21423800-018DW22A	<1	No
Hallway at Classroom 349, Water Bottle Filler	21423800-019WB	2022-06-01	21423800-019WB22A	<1	No
Weight Room 356, Drinking Water Fountain	21423800-020DW	2022-06-01	21423800-020DW22A	<1	No

Weight Room 356, Water Bottle Filler	21423800-021WB	2022-06-01	21423800-021WB22A	<1	No
Auxiliary Gym 357, Drinking Water Fountain	21423800-022DW	2022-06-01	21423800-022DW22A	<1	No
Auxiliary Gym 357, Water Bottle Filler	21423800-023WB	2022-06-01	21423800-023WB22A	<1	No
Training 13, Staff Faucet	21423800-024SF	2022-06-01	21423800-024SF22A	<1	No
Training 13, Ice Machine	21423800-025IM				
Classroom 123, Classroom Faucet	21423800-026CF	2022-06-01	21423800-026CF22A	<1	No
Classroom 123, Drinking Water Fountain	21423800-027DW	2022-06-01	21423800-027DW22A	2.3	No
Hallway at Classroom 124, Left Drinking Water Fountain	21423800-028DW	2022-06-01	21423800-028DW22A	<1	No
Hallway at Classroom 124, Center Spit Fountain	21423800-029OT	2022-06-01	21423800-029OT22A	3.4	No
Hallway at Classroom 124, Right Drinking Water Fountain	21423800-030DW	2022-06-01	21423800-030DW22A	<1	No
Girls Locker Room 16A, Drinking Water Fountain	21423800-031DW	2022-06-01	21423800-031DW22A	<1	No
Classroom 124, Drinking Water Fountain	21423800-032DW	2022-06-01	21423800-032DW22A	1.4	No
Classroom 125, Drinking Water Fountain	21423800-033DW	2022-06-01	21423800-033DW22A	<1	No
Classroom 126, Drinking Water Fountain	21423800-034DW	2022-06-01	21423800-034DW22A	3.3	No
Classroom 127, Classroom Faucet	21423800-035CF	2022-06-01	21423800-035CF22A	1	No
Classroom 127, Drinking Water Fountain	21423800-036DW	2022-06-01	21423800-036DW22A	3.2	No
Classroom 128, Classroom Faucet	21423800-037CF	2022-06-01	21423800-037CF22A	1	No
Classroom 128, Drinking Water Fountain	21423800-038DW	2022-06-01	21423800-038DW22A	2.2	No
Classroom 129, Classroom Faucet	21423800-039CF	2022-06-01	21423800-039CF22A	4.3	No
Classroom 129, Drinking Water Fountain	21423800-040DW	2022-06-01	21423800-040DW22A	<1	No
Teacher Lounge 163, Staff Faucet	21423800-041SF	2022-06-01	21423800-041SF22A	<1	No
Classroom 131, Classroom Faucet	21423800-042CF	2022-06-01	21423800-042CF22A	1.3	No
Classroom 131, Drinking Water Fountain	21423800-043DW	2022-06-01	21423800-043DW22A	2.3	No
Student Store 132, Kitchen Faucet	21423800-044KF	2022-06-01	21423800-044KF22A	<1	No
Kitchen 184, Vegetable Prep Sink in Northeast Portion	21423800-045KF	2022-06-01	21423800-045KF22A	<1	No
Kitchen 184, Kitchen Prep Sink in East Portion, Left Side	21423800-046KF	2022-06-01	21423800-046KF22A	2.4	No
Kitchen 184, Kitchen Prep Sink in East Portion, Right Side	21423800-047KF	2022-06-01	21423800-047KF22A	1.5	No
Kitchen 184, Food Prep Sink in Center Counter	21423800-048KF	2022-06-01	21423800-048KF22A	<1	No
Kitchen 184, Food Prep Sink at South End	21423800-049KF	2022-06-01	21423800-049KF22A	<1	No
Servery 179, Ice Machine	21423800-050IM	2022-06-01	21423800-050IM22A	<1	No
Hallway at Classroom 134, Left Drinking Water Fountain	21423800-051DW	2022-06-01	21423800-051DW22A	<1	No
Hallway at Classroom 134, Right Drinking Water Fountain	21423800-052DW	2022-06-01	21423800-052DW22A	<1	No
Hallway at Entrance to M Wing, Left Drinking Water Fountain	21423800-053DW	2022-06-01	21423800-053DW22A	<1	No

Hallway at Entrance to M Wing, Right Drinking Water Fountain	21423800-054DW	2022-06-01	21423800-054DW22A	<1	No
Hallway at Entrance to M Wing, Water Bottle Filler	21423800-055WB	2022-06-01	21423800-055WB22A	<1	No
Classroom M108, Classroom Faucet	21423800-056CF	2022-06-01	21423800-056CF22A	<1	No
Kitchen M116, Kitchen Faucet	21423800-057KF	2022-06-01	21423800-057KF22A	<1	No
Stage 138, Classroom Faucet	21423800-058CF	2022-06-01	21423800-058CF22A	<1	No
Stage 138, Drinking Water Fountain	21423800-059DW	2022-06-01	21423800-059DW22A	<1	No
Makeup Room M101D	21423800-060CF	2022-06-01	21423800-060CF22A	<1	No
Hallway at Makeup Room M101D, Drinking Water Fountain	21423800-061DW	2022-06-01	21423800-061DW22A	<1	No
Hallway at Makeup Room M101D, Water Bottle Filler	21423800-062WB	2022-06-01	21423800-062WB22A	<1	No
Office 103A, Staff Faucet	21423800-063SF	2022-06-01	21423800-063SF22A	<1	No
Staff Kitchen 103E, Staff Faucet	21423800-064SF	2022-06-01	21423800-064SF22A	<1	No
Hallway at West Side of Auditorium, Left Drinking Water Fountain	21423800-065DW	2022-06-01	21423800-065DW22A	<1	No
Hallway at West Side of Auditorium, Right Drinking Water Fountain	21423800-066DW	2022-06-01	21423800-066DW22A	<1	No
Main Office 104 Mailroom, Staff Faucet	21423800-067SF	2022-06-01	21423800-067SF22A	<1	No
Health 104F, Nurse Sink	21423800-068NS	2022-06-01	21423800-068NS22A	<1	No
Grab & Go 162, Food Prep Sink	21423800-069KF	2022-06-01	21423800-069KF22A	1.8	No
Hallway at Upper Gym, Northwest Side at Classroom 227, Spit Fountain	21423800-070OT	2022-06-01	21423800-070OT22A	2	No
Hallway at Upper Gym, Northwest Side at Classroom 227, Drinking Water Fountain	21423800-071DW	2022-06-01	21423800-071DW22A	<1	No
Classroom 228, Classroom Faucet	21423800-072CF	2022-06-01	21423800-072CF22A	<1	No
Classroom 228, Drinking Water Fountain	21423800-073DW	2022-06-01	21423800-073DW22A	4.2	No
Classroom 229, Classroom Faucet	21423800-074CF	2022-06-01	21423800-074CF22A	<1	No
Classroom 229, Drinking Water Fountain	21423800-075DW	2022-06-01	21423800-075DW22A	2.5	No
Hallway at Restrooms Across from Classroom 432, Left Drinking Water Fountain	21423800-076DW	2022-06-01	21423800-076DW22A	<1	No
Hallway at Restrooms Across from Classroom 432, Right Drinking Water Fountain	21423800-077DW	2022-06-01	21423800-077DW22A	<1	No
Hallway at Restrooms Across from Classroom 432, Water Bottle Filler	21423800-078WB	2022-06-01	21423800-078WB22A	<1	No
Hallway at Classroom 230, Left Drinking Water Fountain	21423800-079DW	2022-06-01	21423800-079DW22A	2	No
Hallway at Classroom 230, Right Drinking Water Fountain	21423800-080DW	2022-06-01	21423800-080DW22A	3.2	No
Hallway at Upper Gym, Northeast Side at Classroom 231, Spit Fountain	21423800-081OT	2022-06-01	21423800-081OT22A	1.3	No
Hallway at Upper Gym, Northeast Side at Classroom 231, Drinking Water Fountain	21423800-082DW	2022-06-01	21423800-082DW22A	<1	No

Classroom 231, Leftmost Classroom Faucet	21423800-083CF	2022-06-01	21423800-083CF22A	1.1	No
Classroom 231, Left Center Classroom Faucet	21423800-084CF	2022-06-01	21423800-084CF22A	4.9	No
Classroom 231, Right Center Classroom Faucet	21423800-085CF	2022-06-01	21423800-085CF22A	6.8	No
Classroom 231, Rightmost Classroom Faucet	21423800-086CF	2022-06-01	21423800-086CF22A	5.6	No
Classroom 232, Leftmost Classroom Faucet	21423800-087CF	2022-06-01	21423800-087CF22A	5.9	No
Classroom 232, Left Center Classroom Faucet	21423800-088CF	2022-06-01	21423800-088CF22A	3.3	No
Classroom 232, Right Center Classroom Faucet	21423800-089CF	2022-06-01	21423800-089CF22A	<1	No
Classroom 232, Rightmost Classroom Faucet	21423800-090CF	2022-06-01	21423800-090CF22A	3.4	No
Classroom 233, Leftmost Classroom Faucet	21423800-091CF	2022-08-11	21423800-091CF22B	7.2	No
Classroom 233, Left of Center Classroom Faucet	21423800-092CF	2022-06-01	21423800-092CF22A	4.7	No
Classroom 233, Left at Center Classroom Faucet	21423800-093CF	2022-06-01	21423800-093CF22A	6.4	No
Classroom 233, Right at Center Classroom Faucet	21423800-094CF	2022-06-01	21423800-094CF22A	4.1	No
Classroom 233, Right of Center Classroom Faucet	21423800-095CF	2022-06-01	21423800-095CF22A	1.9	No
Classroom 233, Rightmost Classroom Faucet	21423800-096CF	2022-06-01	21423800-096CF22A	1	No
Teacher Workroom 237B, Staff Faucet	21423800-097SF	2022-06-01	21423800-097SF22A	<1	No
Hallway at Classroom 242, Left Drinking Water Fountain	21423800-098DW	2022-06-01	21423800-098DW22A	2.8	No
Hallway at Classroom 242, Right Drinking Water Fountain	21423800-099DW	2022-06-01	21423800-099DW22A	<1	No
Hallway at Classroom 201, Left Drinking Water Fountain	21423800-100DW	2022-06-01	21423800-100DW22A	<1	No
Hallway at Classroom 201, Right Drinking Water Fountain	21423800-101DW	2022-06-01	21423800-101DW22A	<1	No
Teacher Workroom 202, Staff Faucet	21423800-102SF	2022-06-01	21423800-102SF22A	<1	No
Teacher Workroom 202, Drinking Water Fountain	21423800-103DW	2022-06-01	21423800-103DW22A	5.9	No
Classroom 214, Classroom Faucet	21423800-104CF	2022-09-15	21423800-104CF22A	<1	No
Classroom 293A Office, Staff Faucet	21423800-105SF	2022-06-01	21423800-105SF22A	<1	No
Classroom 293C Storage, Staff Faucet	21423800-106SF	2022-06-01	21423800-106SF22A	<1	No
Hallway at Custodial CT114, Left Drinking Water Fountain	21423800-107DW	2022-06-01	21423800-107DW22A	<1	No
Hallway at Custodial CT114, Right Drinking Water Fountain	21423800-108DW	2022-06-01	21423800-108DW22A	<1	No
Hallway at Custodial CT114, Water Bottle Filler	21423800-109WB	2022-06-01	21423800-109WB22A	<1	No
Classroom CT104, Left Classroom Faucet	21423800-110CF	2022-06-01	21423800-110CF22A	<1	No
Classroom CT104, Right Classroom Faucet	21423800-111CF	2022-06-01	21423800-111CF22A	<1	No
Classroom CT103, Left Classroom Faucet	21423800-112CF	2022-06-01	21423800-112CF22A	<1	No
Classroom CT104, Right Classroom Faucet	21423800-113CF	2022-06-01	21423800-113CF22A	<1	No

Classroom CT102, Classroom Faucet at Center	21423800-114CF	2022-06-01	21423800-114CF22A	1.7	No
Classroom CT102, Food Prep Sink at West End	21423800-115KF	2022-06-01	21423800-115KF22A	<1	No
Classroom CT102, Food Prep Sink at East End	21423800-116KF	2022-06-01	21423800-116KF22A	<1	No
Classroom CT102, Ice Machine	21423800-117IM	2022-06-01	21423800-117IM22A	1.2	No
Bremik Construction Portable, Classroom Faucet	21423800-118CF	2022-06-01	21423800-118CF22A	1.1	No
Grandstand Concessions, Food Prep Faucet	21423800-119KF	2022-06-01	21423800-119KF22A	10.6	No