

McKinley Elementary School Childcare Fixtures - Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	750
School Name:	McKinley Childcare Facility
Building ID #:	21421800

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Left most drinking fountain in Multi-Purpose Room	21421800-001DW	2022-05-27	21421800-001DW22A	<1	No
Water Bottle Filler in Multi-Purpose Room	21421800-002WB	2022-05-27	21421800-002WB22A	<1	No
Right Side Drinking Fountain in Multi-Purpose Room	21421800-003DW	2022-05-27	21421800-003DW22A	<1	No
Left Drinking Water Fountain in Gym Lobby	21421800-004DW	2022-05-27	21421800-004DW22A	<1	No
Water Bottle Filler in Gym Lobby	21421800-005WB	2022-05-27	21421800-005WB22A	<1	No
Right Side Drinking Water Fountain in Gym Lobby	21421800-006DW	2022-05-27	21421800-006DW22A	<1	No