

McNary High School - 2021 Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	N/A
School Name:	McNary High School
Building ID #:	21423900

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Reception Office Hall at Conference 181	21423900-001-SF	2021-06-29	6292021-21423900-001-SF	<1	No
Concessions at Auditorium	21423900-002-KF	2021-06-29	6292021-21423900-002-KF	4.91	No
Celtic Shop at Auditorium	21423900-003-KF	2021-06-29	6292021-21423900-003-KF	3.36	No
Band Room 41	21423900-004-CF	2021-06-29	6292021-21423900-004-CF	1.04	No
Hall at Library Workroom	21423900-005-DW	2021-11-11	11112021-21423900-005-DW	<1	No
Library Workroom	21423900-006-SF	2021-06-29	6292021-21423900-006-SF	2.45	No
Hall at Custodial 131	21423900-007-WB	2021-06-29	6292021-21423900-007-WB	<1	No
Hall at Custodial 131	21423900-008-DW	2021-06-29	6292021-21423900-008-DW	<1	No
Hall at Custodial 131	21423900-009-DW	2021-06-29	6292021-21423900-009-DW	<1	No
Room 141	21423900-010-CF	2021-06-29	6292021-21423900-010-CF	13.3	No
Hall at Room 67	21423900-011-WB	2021-06-29	6292021-21423900-011-WB	<1	No
Hall at Room 67	21423900-012-DW	2021-06-29	6292021-21423900-012-DW	<1	No
Hall at Room 67	21423900-013-DW	2021-06-29	6292021-21423900-013-DW	<1	No
Room 60	21423900-014-CF	2021-06-29	6292021-21423900-014-CF	<1	No
Weight Room 59	21423900-015-WB	2021-11-11	11112021-21423900-015-WB	<1	No
Weight Room 59	21423900-016-DW	2021-11-11	11112021-21423900-016-DW	<1	No
Weight Room 59	21423900-017-DW	2021-11-11	11112021-21423900-017-DW	<1	No
Graphic Design Room 58	21423900-018-CF	2021-06-29	6292021-21423900-018-CF	7.07	No
Graphic Design Room 58	21423900-019-CF	2021-06-29	6292021-21423900-019-CF	1.14	No
Hall at Diesel Shop 51	21423900-020-WB	2021-06-29	6292021-21423900-020-WB	<1	No
Hall at Diesel Shop 51	21423900-021-DW	2021-06-29	6292021-21423900-021-DW	<1	No
Hall at Diesel Shop 51	21423900-022-DW	2021-06-29	6292021-21423900-022-DW	<1	No
Room 147	21423900-023-DW	2021-06-29	6292021-21423900-023-DW	2.91	No
Room 147	21423900-024-CF	2021-06-29	6292021-21423900-024-CF	2.24	No
Room 145	21423900-025-DW	2021-06-29	6292021-21423900-025-DW	6.64	No
Room 145	21423900-026-CF	2021-06-29	6292021-21423900-026-CF	2.06	No

Room 143	21423900-027-DW	2021-06-29	6292021-21423900-027-DW	4.43	No
Room 143	21423900-028-CF	2021-06-29	6292021-21423900-028-CF	3.73	No
Hall at 143	21423900-029-DW	2021-06-29	6292021-21423900-029-DW	<1	No
Hall at 143	21423900-030-DW	2021-06-29	6292021-21423900-030-DW	<1	No
Room 141	21423900-031-DW	2021-06-29	6292021-21423900-031-DW	5.2	No
Room 141	21423900-032-CF	2021-06-29	6292021-21423900-032-CF	7.94	No
Hall at Custodial 151	21423900-033-DW	2021-06-29	6292021-21423900-033-DW	<1	No
Hall at Custodial 151	21423900-034-DW	2021-06-29	6292021-21423900-034-DW	1.13	No
Girls Locker Room South	21423900-035-DW	2021-06-29	6292021-21423900-035-DW	6.15	No
Girls Locker Room North - REMOVED	21423900-036-DW				
Gym Northeast	21423900-037-DW	2021-06-29	6292021-21423900-037-DW	<1	No
Gym Southwest	21423900-038-DW	2021-06-29	6292021-21423900-038-DW	1.58	No
Boys Locker Room North Hall	21423900-039-DW	2021-06-29	6292021-21423900-039-DW	4.41	No
Boys Locker Room North Hall	21423900-040-DW	2021-06-29	6292021-21423900-040-DW	5.06	No
Athletic Office 160	21423900-041-IM	2021-06-29	6292021-21423900-041-IM	<1	No
Athletic Office 160	21423900-042-CF	2021-06-29	6292021-21423900-042-CF	1.73	No
Room 159	21423900-043-CF	2021-06-29	6292021-21423900-043-CF	<1	No
Room 159 Food Prep	21423900-044-CF	2021-06-29	6292021-21423900-044-CF	<1	No
Room 159 Wash Sink	21423900-045-CF	2021-06-29	6292021-21423900-045-CF	<1	No
Room 159 Wash Sink	21423900-046-CF	2021-06-29	6292021-21423900-046-CF	<1	No
Room 159 Wash Sink	21423900-047-CF	2021-06-29	6292021-21423900-047-CF	<1	No
Room 158	21423900-048-CF	2021-06-29	6292021-21423900-048-CF	<1	No
Room 158	21423900-049-CF	2021-06-29	6292021-21423900-049-CF	<1	No
Room 158	21423900-050-CF	2021-06-29	6292021-21423900-050-CF	<1	No
Room 158	21423900-051-CF	2021-06-29	6292021-21423900-051-CF	<1	No
Room 158	21423900-052-IM	2021-06-29	6292021-21423900-052-IM	<1	No
Room 158	21423900-053-CF	2021-06-29	6292021-21423900-053-CF	<1	No
Room 158	21423900-054-CF	2021-06-29	6292021-21423900-054-CF	<1	No
Room 158	21423900-055-CF	2021-06-29	6292021-21423900-055-CF	1.42	No
Hall at Cafeteria	21423900-056-DW	2022-02-02	222022-21423900-056-DW	1.3	No
Cafeteria	21423900-057-DW	2021-06-29	6292021-21423900-057-DW	<1	No
Cafeteria	21423900-058-DW	2021-06-29	6292021-21423900-058-DW	<1	No
Cafeteria	21423900-059-WB	2021-06-29	6292021-21423900-059-WB	<1	No
Kitchen North Section	21423900-060-KF	2021-06-29	6292021-21423900-060-KF	6.23	No
Kitchen North Section	21423900-061-KF	2021-06-29	6292021-21423900-061-KF	1.1	No
Kitchen North Section	21423900-062-KF	2021-06-29	6292021-21423900-062-KF	1.22	No
Kitchen North Section	21423900-063-IM	2021-06-29	6292021-21423900-063-IM	<1	No
Kitchen Southeast Section	21423900-064-KF	2021-06-29	6292021-21423900-064-KF	<1	No
Kitchen Southeast Section	21423900-065-KF	2021-06-29	6292021-21423900-065-KF	2.4	No

Work Room 124C	21423900-066-SF	2021-06-29	6292021-21423900-066-SF	2.98	No
Room 254	21423900-067-SF	2021-06-29	6292021-21423900-067-SF	4.01	No
Room 206	21423900-068-SF	2021-06-29	6292021-21423900-068-SF	<1	No
Room 210	21423900-069-CF	2021-06-29	6292021-21423900-069-CF	2.98	No
Staff Room 215	21423900-070-SF	2021-06-29	6292021-21423900-070-SF	<1	No
Hall at Custodian 217	21423900-071-DW	2022-02-02	222022-21423900-071-DW	<1	No
Hall at Custodian 217	21423900-072-DW	2022-02-02	222022-21423900-072-DW	<1	No
Hall at Custodian 217	21423900-073-DW	2021-06-29	6292021-21423900-073-DW	5.85	No
Hall at Custodian 217	21423900-074-DW	2022-02-02	222022-21423900-074-DW	6.1	No
Room 221	21423900-075-SF	2021-06-29	6292021-21423900-075-SF	8.27	No
Room 229A	21423900-076-SF	2021-06-29	6292021-21423900-076-SF	4.58	No
Hall at 294	21423900-077-WB	2021-06-29	6292021-21423900-077-WB	<1	No
Hall at 294	21423900-078-DW	2021-06-29	6292021-21423900-078-DW	<1	No
Hall at 294	21423900-079-DW	2021-06-29	6292021-21423900-079-DW	<1	No
Hall at 280	21423900-080-WB	2021-06-29	6292021-21423900-080-WB	<1	No
Hall at 280	21423900-081-DW	2021-06-29	6292021-21423900-081-DW	<1	No
Hall at 280	21423900-082-DW	2021-06-29	6292021-21423900-082-DW	<1	No
Room 244	21423900-083-CF	2021-06-29	6292021-21423900-083-CF	6.48	No
Room 245	21423900-084-CF	2021-06-29	6292021-21423900-084-CF	<1	No
Hall at 235	21423900-085-DW	2021-06-29	6292021-21423900-085-DW	2.17	No
Hall at 235	21423900-086-DW	2021-06-29	6292021-21423900-086-DW	17.6	Yes
Hall at 235 - Resample	21423900-086-DW	2022-02-16	2162022-21423900-086-DW	<1	No
Room 233	21423900-087-CF	2021-06-29	6292021-21423900-087-CF	1.48	No
Hall at Girls Restroom 248	21423900-088-WB	2021-06-29	6292021-21423900-088-WB	<1	No
Hall at Girls Restroom 248	21423900-089-DW	2021-06-29	6292021-21423900-089-DW	<1	No
Hall at 258	21423900-090-DW	2021-06-29	6292021-21423900-090-DW	<1	No
Room 261	21423900-091-CF	2021-06-29	6292021-21423900-091-CF	4.65	No
West Balcony Gym 267	21423900-092-WB	2021-06-29	6292021-21423900-092-WB	<1	No
West Balcony Gym 267	21423900-093-DW	2021-06-29	6292021-21423900-093-DW	<1	No
West Balcony Gym 267	21423900-094-DW	2021-06-29	6292021-21423900-094-DW	<1	No
East Balcony Gym 268	21423900-095-WB	2021-06-29	6292021-21423900-095-WB	<1	No
East Balcony Gym 268	21423900-096-DW	2022-02-02	222022-21423900-096-DW	<1	No
East Balcony Gym 268	21423900-097-DW	2022-02-02	222022-21423900-097-DW	<1	No

Notes:

Fixtures that test above 15 ppb during the initial sampling event are taken out of service, repaired/replaced and then retested prior to returning to service.