

## Miller Elementary School - 2021 Drinking Water Sampling Results

<b>Inst. Name:</b>	Salem-Keizer Public Schools
<b>Inst. ID #:</b>	N/A
<b>School Name:</b>	Miller Elementary School
<b>Building ID #:</b>	21414800

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Main Office Health Room	21414800-001-DW	2021-06-25	6252021-21414800-001-DW	1	No
Main Office Health Room	21414800-002-NS	2021-06-25	6252021-21414800-002-NS	2.85	No
Main Office Mail Room	21414800-003-DW	2021-06-25	6252021-21414800-003-DW	1.05	No
Main Office Mail Room	21414800-004-SF	2021-06-25	6252021-21414800-004-SF	1.62	No
Staff Lounge	21414800-005-SF	2021-06-25	6252021-21414800-005-SF	<1	No
Staff Lounge Instant Hot Faucet	21414800-006-SF	2021-06-25	6252021-21414800-006-SF	<1	No
Room A10	21414800-007-DW	2021-06-25	6252021-21414800-007-DW	<1	No
Room A10	21414800-008-CF	2021-06-25	6252021-21414800-008-CF	1.12	No
Room A20	21414800-009-DW	2021-06-25	6252021-21414800-009-DW	1.34	No
Room A20	21414800-010-CF	2021-06-25	6252021-21414800-010-CF	1.03	No
Room A30	21414800-011-DW	2021-06-25	6252021-21414800-011-DW	1.55	No
Room A30	21414800-012-CF	2021-06-25	6252021-21414800-012-CF	1.1	No
Room A40	21414800-013-DW	2021-06-25	6252021-21414800-013-DW	1.79	No
Room A40	21414800-014-CF	2021-06-25	6252021-21414800-014-CF	<1	No
Room A50	21414800-015-DW	2021-06-25	6252021-21414800-015-DW	1.55	No
Room A50	21414800-016-CF	2021-06-25	6252021-21414800-016-CF	9.81	No
Room A60	21414800-017-DW	2021-06-25	6252021-21414800-017-DW	5.17	No
<b>Room A60</b>	<b>21414800-018-CF</b>	<b>2021-06-25</b>	<b>6252021-21414800-018-CF</b>	<b>17.6</b>	<b>Yes</b>
<b>Room A60 - Resample</b>	<b>21414800-018-CF</b>	<b>2022-02-16</b>	<b>2162022-21414800-018-CF</b>	<b>4.8</b>	<b>No</b>
Room A70	21414800-019-DW	2021-06-25	6252021-21414800-019-DW	<1	No
Room A70	21414800-020-CF	2021-06-25	6252021-21414800-020-CF	1.75	No
Library	21414800-021-CF	2021-06-25	6252021-21414800-021-CF	<1	No
Room B10	21414800-022-DW	2021-06-25	6252021-21414800-022-DW	2.91	No
Room B10	21414800-023-CF	2021-06-25	6252021-21414800-023-CF	3.62	No
Room B20	21414800-024-DW	2021-06-25	6252021-21414800-024-DW	2.1	No
Room B20	21414800-025-CF	2021-06-25	6252021-21414800-025-CF	1.28	No

Room B30	21414800-026-DW	2021-06-25	6252021-21414800-026-DW	1.59	No
Room B30	21414800-027-CF	2021-06-25	6252021-21414800-027-CF	1.16	No
Room B40	21414800-028-DW	2021-06-25	6252021-21414800-028-DW	3.52	No
Room B40	21414800-029-CF	2021-06-25	6252021-21414800-029-CF	2.93	No
Room B50	21414800-030-DW	2021-06-25	6252021-21414800-030-DW	1.77	No
Room B50	21414800-031-CF	2021-06-25	6252021-21414800-031-CF	2.5	No
Room B60	21414800-032-DW	2021-06-25	6252021-21414800-032-DW	1.79	No
Room B60	21414800-033-CF	2021-06-25	6252021-21414800-033-CF	2.13	No
Room CR M1	21414800-034-DW	2021-06-25	6252021-21414800-034-DW	1.2	No
Room CR M1	21414800-035-CF	2021-06-25	6252021-21414800-035-CF	<1	No
Room CR M2	21414800-036-DW	2021-06-25	6252021-21414800-036-DW	<1	No
Room CR M2	21414800-037-CF	2021-06-25	6252021-21414800-037-CF	1.6	No
Room CR M3	21414800-038-DW	2021-06-25	6252021-21414800-038-DW	1.28	No
Room CR M3	21414800-039-CF	2021-06-25	6252021-21414800-039-CF	<1	No
Room CR M4	21414800-040-DW	2021-06-25	6252021-21414800-040-DW	1.27	No
Room CR M4	21414800-041-CF	2021-06-25	6252021-21414800-041-CF	<1	No
Room CR M5	21414800-042-DW	2021-06-25	6252021-21414800-042-DW	1.87	No
Room CR M5	21414800-043-CF	2021-06-25	6252021-21414800-043-CF	<1	No
Room C10	21414800-044-DW	2021-06-25	6252021-21414800-044-DW	<1	No
Room C10	21414800-045-CF	2021-06-25	6252021-21414800-045-CF	1.04	No
Room C20	21414800-046-DW	2021-06-25	6252021-21414800-046-DW	2.43	No
Room C20	21414800-047-CF	2021-06-25	6252021-21414800-047-CF	1.9	No
Room C30	21414800-048-DW	2021-06-25	6252021-21414800-048-DW	1.82	No
Room C30	21414800-049-CF	2021-06-25	6252021-21414800-049-CF	2.7	No
Room C40	21414800-050-DW	2021-06-25	6252021-21414800-050-DW	1.03	No
Room C40	21414800-051-CF	2021-06-25	6252021-21414800-051-CF	1.86	No
Room C50	21414800-052-DW	2021-06-25	6252021-21414800-052-DW	2.34	No
Room C50	21414800-053-CF	2021-06-25	6252021-21414800-053-CF	2.43	No
Room C60	21414800-054-DW	2021-06-25	6252021-21414800-054-DW	3.24	No
Room C60	21414800-055-CF	2021-06-25	6252021-21414800-055-CF	1.96	No
Music Room E10	21414800-056-DW	2022-02-01	212022-21414800-056-DW	1.2	No
Music Room E10	21414800-057-CF	2022-02-01	212022-21414800-057-CF	8	No
Gym	21414800-058-DW	2022-02-01	212022-21414800-058-DW	1	No
Kitchen Prep	21414800-059-KF	2021-06-25	6252021-21414800-059-KF	3.1	No
Cafeteria MP16A Closet Sink	21414800-060-CF	2021-06-25	6252021-21414800-060-CF	1.89	No

**Notes:**

Fixtures that test above 15 ppb during the initial sampling event are taken out of service, repaired/replaced and then retested prior to returning to service.