

Myers Elementary School - 2022 Lead in Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	754
School Name:	Myers Elementary School
Building ID #:	21422100

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Gym, Drinking Water Fountain	21422100-001DW	2022-09-15	21422100-001DW23A	1.4	No
Hallway at Gym, Drinking Water Fountain	21422100-002DW	2022-09-15	21422100-002DW23A	14.3 - 43.9	Yes
CE Staff Lounge	21422100-003SF	2022-09-15	21422100-003SF23A	5.6	No
Food Service Room	21422100-004KF	2022-09-15	21422100-004KF23A	25	Yes
Room 113, Left Sink	21422100-005CF	2022-09-15	21422100-005CF23A	33	Yes
Room 113, Right Sink	21422100-006CF	2022-09-15	21422100-006CF23A	16.9	Yes
Room 113, Right Sink	21422100-007DW	2022-09-15	21422100-007DW23A	13.2	No
Room 115, Far Wall	21422100-008CF	2022-09-15	21422100-008CF23A	30.4	Yes
West Wing, Boy's Restroom Entry	21422100-009DW	2022-09-15	21422100-009DW23A	1.2	No
Room 116, Far Wall	21422100-010CF	2022-09-15	21422100-010CF23A	8.1	No
Room 116, Far Wall	21422100-011DW	2022-09-15	21422100-011DW23A	3.5	No
Room 117, Far Corner	21422100-012CF	2022-09-15	21422100-012CF23A	2.2	No
Room 117, Far Corner	21422100-013DW	2022-09-15	21422100-013DW23A	1.8	No
Room 118, Far Wall	21422100-014CF	2022-09-15	21422100-014CF23A	3.2	No
Room 118, Far Wall	21422100-015DW	2022-09-15	21422100-015DW23A	2.8	No
Room 119, Far Wall	21422100-016CF	2022-09-15	21422100-016CF23A	12.8	No
Room 119, Far Wall	21422100-017DW	2022-09-15	21422100-017DW23A	9.5	No
Room 120, Far Corner	21422100-018CF	2022-09-15	21422100-018CF23A	15.4	Yes
Room 120, Far Corner	21422100-019DW	2022-09-15	21422100-019DW23A	17.2	Yes
Room 121, LRC Room, Back Corner	21422100-020CF	2022-09-15	21422100-020CF23A	17.2	Yes
Room 121, LRC Room, Back Corner	21422100-021DW	2022-09-15	21422100-021DW23A	8.9	No
West Wing, Girl's Restroom Entry	21422100-022DW	2022-09-15	21422100-022DW23A	4.6	No
Rom 124, Back Wall	21422100-023CF	2022-09-15	21422100-023CF23A	2.6	No
Office, Health Room	21422100-024NS	2022-09-15	21422100-024NS23A	6.3	No
Office, Health Room	21422100-025DW	2022-09-15	21422100-025DW23A	2.4	No
Hall Outside of Speech Room	21422100-026SF	2022-09-15	21422100-026SF23A	53.9	Yes

Room 101, Far Wall	21422100-027CF	2022-09-15	21422100-027CF23A	51.7	Yes
Room 101, Far Wall	21422100-028DW	2022-09-15	21422100-028DW23A	3.2	No
Room 102, Far Corner	21422100-029CF	2022-09-15	21422100-029CF23A	2	No
Room 102, Far Corner	21422100-030DW	2022-09-15	21422100-030DW23A	1.8	No
Room 103, Far Corner	21422100-031CF	2022-09-15	21422100-031CF23A	7	No
Room 103, Far Corner	21422100-032DW	2022-09-15	21422100-032DW23A	3.2	No
Room 131, Far Wall	21422100-033CF	2022-09-15	21422100-033CF23A	<1	No
Room 131, Far Wall	21422100-034DW	2022-09-15	21422100-034DW23A	<1	No
Room 133, Right of Room Entry	21422100-035CF	2022-09-15	21422100-035CF23A	<1	No
Room 133, Right of Room Entry	21422100-036DW	2022-09-15	21422100-036DW23A	<1	No
Room 132, Left of Room Entry	21422100-037DW	2022-09-15	21422100-037DW23A	<1	No
Room 132, Left of Room Entry	21422100-038CF	2022-09-15	21422100-038CF23A	<1	No
Room 105, Far Corner	21422100-039CF	2022-09-15	21422100-039CF23A	3.3	No
Room 105, Far Corner	21422100-040DW	2022-09-15	21422100-040DW23A	2.9	No
Hallway, Outside of NE Restrooms	21422100-041DW	2022-09-15	21422100-041DW23A	8.9	No
Room 104, Back Corner	21422100-042CF	2022-09-15	21422100-042CF23A	14	No
Room 104, Back Corner	21422100-043DW	2022-09-15	21422100-043DW23A	3	No
Room 106, Back Wall	21422100-044CF	2022-09-15	21422100-044CF23A	15.8	Yes
Room 106, Back Wall	21422100-045DW	2022-09-15	21422100-045DW23A	3.6	No
Lounge, Right of Room Entry	21422100-046SF	2022-09-15	21422100-046SF23A	<1	No
Lounge, Lactation Room	21422100-047SF	2022-09-15	21422100-047SF23A	<1	No
Cafeteria Entry	21422100-048WB	2022-09-15	21422100-048WB23A	<1	No
Cafeteria Entry	21422100-049DW	2022-09-15	21422100-049DW23A	<1	No
Cafeteria Entry	21422100-050DW	2022-09-15	21422100-050DW23A	<1	No
Kitchen, Center Wall, Pot Filler	21422100-051KF	2022-09-15	21422100-051KF23A	11.9	No
Kitchen, Far Left Wall	21422100-052KF	2022-09-15	21422100-052KF23A	1.2	No
Kitchen, Center Table to Left of Kitchen Entry	21422100-053KF	2022-09-15	21422100-053KF23A	<1	No
Room 110, Far Back Wall	21422100-054CF	2022-09-15	21422100-054CF23A	15.5	Yes
Room 110, Far Back Wall	21422100-055DW	2022-09-15	21422100-055DW23A	1.5	No
Room 109, Far Wall	21422100-056CF	2022-09-15	21422100-056CF23A	<1	No
Room 109, Back Wall	21422100-057DW	2022-09-15	21422100-057DW23A	3.2	No
Computer Lab, Middle of Wall	21422100-058CF	2022-09-15	21422100-058CF23A	14.1	No
Computer Lab, Middle of Wall	21422100-059DW	2022-09-15	21422100-059DW23A	2.7	No
Room 112, Far Back Wall	21422100-060CF	2022-09-15	21422100-060CF23A	5.5	No
Room 112, Far Back Wall	21422100-061DW	2022-09-15	21422100-061DW23A	3.2	No
Room 111, Far Back Corner	21422100-062CF	2022-09-15	21422100-062CF23A	3.5	No
Room 111, Far Back Corner	21422100-063DW	2022-09-15	21422100-063DW23A	<1	No

All fixtures above that are bolded were removed from service immediately, and will remain out of service until remedial actions are taken and the fixtures are resampled and are below EPA's Action Level.