

North Salem High School - 2021 Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	N/A
School Name:	North Salem High School
Building ID #:	21424000

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Nurse's office	21424000-001-NS	2021-06-30	6302021-21424000-001-NS	<1	No
Weight room left	21424000-002-DW	2021-11-11	11112021-21424000-002-DW	<1	No
Weight room right	21424000-003-DW	2021-11-11	11112021-21424000-003-DW	<1	No
Weight room bottle filler	21424000-004-WB	2021-06-30	6302021-21424000-004-WB	<1	No
Gym hallway	21424000-005-DW	2021-11-11	11112021-21424000-005-DW	<1	No
Gym hallway	21424000-006-DW	2021-11-11	11112021-21424000-006-DW	<1	No
Gym hallway	21424000-007-WB	2021-06-30	6302021-21424000-007-WB	<1	No
Training Room Ice	21424000-008-IM	2021-06-30	6302021-21424000-008-IM	<1	No
Training sink	21424000-009-NS	2021-06-30	6302021-21424000-009-NS	<1	No
Crushed ice machine	21424000-010-IM	2021-06-30	6302021-21424000-010-IM	<1	No
Soaking tub main faucet	21424000-011-OT	2021-06-30	6302021-21424000-011-OT	16.9	Yes
Soaking tub main faucet - Resample	21424000-011-OT	2022-02-18	2182022-21424000-011-OT	8.7	No
Soaking tub	21424000-012-OT	2021-06-30	6302021-21424000-012-OT	6.5	No
Bathroom sink off office	21424000-013-BF	2021-06-30	6302021-21424000-013-BF	<1	No
Concession area	21424000-014-KF	2021-06-30	6302021-21424000-014-KF	1.1	No
Concession area	21424000-015-KF	2021-06-30	6302021-21424000-015-KF	<1	No
Room 1020	21424000-016-CF	2021-06-30	6302021-21424000-016-CF	<1	No
1000 & 1005 kitchen	21424000-017-KF	2021-06-30	6302021-21424000-017-KF	<1	No
Custodial office	21424000-018-SF	2021-06-30	6302021-21424000-018-SF	<1	No
Left	21424000-019-DW	2021-06-30	6302021-21424000-019-DW	4	No
Center	21424000-020-DW	2021-06-30	6302021-21424000-020-DW	<1	No
Right	21424000-021-DW	2021-06-30	6302021-21424000-021-DW	2.4	No
Home ec alcove	21424000-022-CF	2021-06-30	6302021-21424000-022-CF	<1	No
U<1er sink across from entrance	21424000-023-IM	2021-11-11	11112021-21424000-023-IM	<1	No
Across from entrance	21424000-024-CF	2021-06-30	6302021-21424000-024-CF	<1	No
Station 1	21424000-025-CF	2021-06-30	6302021-21424000-025-CF	<1	No

Station 2	21424000-026-CF	2021-06-30	6302021-21424000-026-CF	<1	No
Station 3	21424000-027-CF	2021-06-30	6302021-21424000-027-CF	2.5	No
Station 4	21424000-028-CF	2021-06-30	6302021-21424000-028-CF	1.6	No
Station 5	21424000-029-CF	2021-06-30	6302021-21424000-029-CF	2	No
Station 6	21424000-030-CF	2021-06-30	6302021-21424000-030-CF	9.9	No
Room 101	21424000-031-CF	2021-06-30	6302021-21424000-031-CF	<1	No
Room101	21424000-032-CF	2021-06-30	6302021-21424000-032-CF	<1	No
Room 101	21424000-033-CF	2021-06-30	6302021-21424000-033-CF	<1	No
Room101	21424000-034-CF	2021-06-30	6302021-21424000-034-CF	1.5	No
Room 101	21424000-035-CF	2021-06-30	6302021-21424000-035-CF	1.7	No
Counseling office	21424000-036-SF	2021-06-30	6302021-21424000-036-SF	1	No
Crossroads cafe	21424000-037-IM	2021-06-30	6302021-21424000-037-IM	<1	No
Red cabinet sink	21424000-038-KF	2021-06-30	6302021-21424000-038-KF	3.6	No
Red cabinet sink right	21424000-039-KF	2021-06-30	6302021-21424000-039-KF	8.4	No
Dish washing	21424000-040-KF	2021-06-30	6302021-21424000-040-KF	1.2	No
Fountain outside coffee shack	21424000-041-DW	2021-06-30	6302021-21424000-041-DW	1.2	No
Espresso maker	21424000-042-OT	2021-06-30	6302021-21424000-042-OT	8.7	No
Coffee bar sink	21424000-043-KF	2021-06-30	6302021-21424000-043-KF	5	No
Coffee bar ice	21424000-044-IM	2021-06-30	6302021-21424000-044-IM	2.3	No
Library sink	21424000-045-SF	2021-06-30	6302021-21424000-045-SF	<1	No
Library book storage	21424000-046-SF	2021-06-30	6302021-21424000-046-SF	<1	No
Library fountain	21424000-047-DW	2021-06-30	6302021-21424000-047-DW	<1	No
Library fountain	21424000-048-DW	2021-06-30	6302021-21424000-048-DW	<1	No
Library bottle filler	21424000-049-WB	2021-06-30	6302021-21424000-049-WB	<1	No
Room 134	21424000-050-CF	2021-06-30	6302021-21424000-050-CF	4.5	No
Staff men fountain left	21424000-051-DW	2021-06-30	6302021-21424000-051-DW	<1	No
Staff men fountain center	21424000-052-DW	2021-06-30	6302021-21424000-052-DW	<1	No
Staff men fountain right	21424000-053-DW	2021-06-30	6302021-21424000-053-DW	<1	No
Room 122	21424000-054-CF	2021-06-30	6302021-21424000-054-CF	<1	No
Room 121	21424000-055-CF	2021-06-30	6302021-21424000-055-CF	2.1	No
Room 121	21424000-056-CF	2021-06-30	6302021-21424000-056-CF	<1	No
Room303 orchestra	21424000-057-CF	2021-06-30	6302021-21424000-057-CF	2	No
Band room 120	21424000-058-CF	2021-06-30	6302021-21424000-058-CF	3.1	No
Kitchen back wall	21424000-059-KF	2021-06-30	6302021-21424000-059-KF	4.8	No
Middle wall	21424000-060-KF	2021-06-30	6302021-21424000-060-KF	<1	No
Cafeteria fountain	21424000-061-DW	2021-11-11	11112021-21424000-061-DW	<1	No
Cafeteria fountain	21424000-062-DW	2021-11-11	11112021-21424000-062-DW	<1	No
Cafeteria water bottle filler	21424000-063-WB	2021-06-30	6302021-21424000-063-WB	<1	No
Room 402	21424000-064-CF	2021-06-30	6302021-21424000-064-CF	3.2	No

Room 402	21424000-065-CF	2021-06-30	6302021-21424000-065-CF	<1	No
Room 413	21424000-066-CF	2021-06-30	6302021-21424000-066-CF	3	No
Locker area	21424000-067-SF	2021-06-30	6302021-21424000-067-SF	<1	No
Play area	21424000-068-CF	2021-06-30	6302021-21424000-068-CF	<1	No
Play area	21424000-069-CF	2021-06-30	6302021-21424000-069-CF	<1	No
Kitchen food prep sink	21424000-070-KF	2021-06-30	6302021-21424000-070-KF	10.2	No
Kitchen hand wash sink	21424000-071-KF	2021-06-30	6302021-21424000-071-KF	4.4	No
Room 206	21424000-072-CF	2021-06-30	6302021-21424000-072-CF	14.7	No
Room 206	21424000-073-DW	2021-06-30	6302021-21424000-073-DW	9.6	No
Second Floor Staff Room near 212	21424000-074-SF	2021-06-30	6302021-21424000-074-SF	2.5	No
Second Floor Hall at Wrestling Room 2110	21424000-075-DW	2022-01-28	1282022-21424000-075-DW	<1	No
Second Floor Hall at Wrestling Room 2110	21424000-076-DW	2022-01-28	1282022-21424000-076-DW	<1	No
Second Floor Hall at Wrestling Room 2110	21424000-077-WB	2021-06-30	6302021-21424000-077-WB	<1	No
Room 2115	21424000-078-CF	2021-06-30	6302021-21424000-078-CF	<1	No
Room 2115	21424000-079-CF	2021-06-30	6302021-21424000-079-CF	<1	No
Room 227	21424000-080-CF	2021-06-30	6302021-21424000-080-CF	<1	No
Room 227	21424000-081-CF	2021-06-30	6302021-21424000-081-CF	1	No
Room 226	21424000-082-CF	2021-06-30	6302021-21424000-082-CF	1	No
Room 226	21424000-083-CF	2021-06-30	6302021-21424000-083-CF	<1	No
Room 224	21424000-084-CF	2021-06-30	6302021-21424000-084-CF	2.6	No
Room 228	21424000-085-CF	2021-06-30	6302021-21424000-085-CF	2.6	No
Room 229	21424000-086-CF	2021-06-30	6302021-21424000-086-CF	1.8	No
Room 230	21424000-087-CF	2021-06-30	6302021-21424000-087-CF	2.1	No
Room 223	21424000-088-CF	2021-06-30	6302021-21424000-088-CF	2	No
Room 223	21424000-089-CF	2021-06-30	6302021-21424000-089-CF	3.1	No
Room 222	21424000-090-CF	2021-06-30	6302021-21424000-090-CF	2.2	No
Room 222	21424000-091-CF	2021-06-30	6302021-21424000-091-CF	6.6	No
Hall at 221	21424000-092-DW	2021-06-30	6302021-21424000-092-DW	<1	No
Room 233 Prep Subroom 220	21424000-093-SF	2021-06-30	6302021-21424000-093-SF	<1	No
Workroom 234	21424000-094-SF	2021-06-30	6302021-21424000-094-SF	4.5	No
Hall at 236	21424000-095-DW	2021-06-30	6302021-21424000-095-DW	<1	No
Hall at 236	21424000-096-DW	2021-06-30	6302021-21424000-096-DW	<1	No
Hall at 236	21424000-097-DW	2021-06-30	6302021-21424000-097-DW	<1	No
Room 238	21424000-098-CF	2021-06-30	6302021-21424000-098-CF	23.7	Yes
Room 238 - Resample	21424000-098-CF	2022-02-16	2162022-21424000-098-CF	4	No
Room 239	21424000-099-CF	2021-06-30	6302021-21424000-099-CF	<1	No
Workroom 240	21424000-100-SF	2021-06-30	6302021-21424000-100-SF	2	No
Workroom off 241	21424000-101-SF	2021-06-30	6302021-21424000-101-SF	2.9	No
Prep Room 242 off 243	21424000-102-SF	2021-06-30	6302021-21424000-102-SF	1.5	No

Hall at 243	21424000-103-DW	2021-06-30	6302021-21424000-103-DW	<1	No
Hall at 243	21424000-104-WB	2021-06-30	6302021-21424000-104-WB	<1	No
Fountain outside choir	21424000-105-DW	2022-01-28	1282022-21424000-105-DW	<1	No
Fountain outside choir	21424000-106-DW	2021-06-30	6302021-21424000-106-DW	<1	No
Fountain outside 210 left	21424000-107-DW	2021-06-30	6302021-21424000-107-DW	<1	No
Fountain outside 210 center	21424000-108-DW	2021-06-30	6302021-21424000-108-DW	1.1	No
Fountain outside 210 right	21424000-109-DW	2021-06-30	6302021-21424000-109-DW	2	No
400 Building Hallway	21424000-110-DW	2021-06-30	6302021-21424000-110-DW	<1	No

Notes:

Fixtures that test above 15 ppb during the initial sampling event are taken out of service, repaired/replaced and then retested prior to returning to service.