

Olinger Pool - 2022 Lead in Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	773
School Name:	Olinger Pool
Building ID #:	21424001

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Main Room at Men's Locker Room, Left Drinking Water Fountain	21424001-001DW	2022-05-20	21424001-001DW22A	1.3	No
Main Room at Men's Locker Room, Right Drinking Water Fountain	21424001-002DW	2022-05-20	21424001-002DW22A	2	No
Main Room at Men's Locker Room, Water Bottle Filler	21424001-003WB	2022-05-20	21424001-003WB22A	1.6	No
Small Room off South Lobby, Staff Faucet	21424001-004SF	2022-05-20	21424001-004SF22A	14.1	No