

Paulus Administration Center - 2022 Lead in Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	2142
School Name:	Paulus Administration Center
Building ID #:	21420008

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result for Lead in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Drinking Water Fountain, Outside Room 207	21420008-001DW	2022-10-07	21420008-001DW23B	9.9	No
Staff Faucet, Room 210	21420008-002SF	2022-08-10	21420008-002SF23A	6.4	No
Drinking Water Fountain, Outside Room 210	21420008-003DW	2022-08-10	21420008-003DW23A	<1	No
Staff Faucet, Break Room Across Room 217	21420008-004SF	2022-08-10	21420008-004SF23A	1	No
Staff Faucet, Room 207	21420008-005SF	2022-08-10	21420008-005SF23A	14.8	No
Drinking Water Fountain, Outside Women's Restroom/Across From Room 104	21420008-006DW	2022-11-11	21420008-006DW23C	4.5	No
Drinking Water Fountain, Near Room 116 and Dump Station	21420008-007DW	2022-08-10	21420008-007DW23A	<1	No
Staff Faucet, Room 108	21420008-008SF	2022-08-10	21420008-008SF23A	2.2	No