

Salem Heights Elementary School Childcare Fixtures - Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	759
School Name:	Salem Heights Childcare Facility
Building ID #:	21422500

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Drinking Water Fountain in Gym Entry Vestibule	21422500-001DW	2022-05-27	21422500-001DW22A	1	No