

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Salem Heights Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Collected	Container ID	Tested For	Results	Action Level
047-01A	Staff Lounge Refrigerator Ice Maker	7/29/16 8:50 AM	8/5/2016	1608142-01A	LEAD	<1.0 PPB	15 PPB
047-02A	Staff Lounge Sink Faucet	7/29/16 8:52 AM	8/5/2016	1608142-02A	LEAD	<1.0 PPB	15 PPB
047-03A	Hall Drinking Fountain 1	7/29/16 9:00 AM	8/5/2016	1608142-03A	LEAD	5 PPB	15 PPB
047-04A	Classroom 6 Sink Faucet	7/29/16 10:02 AM	8/5/2016	1608142-04A	LEAD	<1.0 PPB	15 PPB
047-05A	Classroom 6 Drinking Fountain	7/29/16 10:02 AM	8/5/2016	1608142-05A	LEAD	5 PPB	15 PPB
047-06A	Classroom 5 Sink Faucet	7/29/16 10:06 AM	8/5/2016	1608142-06A	LEAD	1 PPB	15 PPB
047-07A	Classroom 5 Drinking Fountain	7/29/16 10:06 AM	8/5/2016	1608142-07A	LEAD	4 PPB	15 PPB
047-08A	Classroom 4 Sink Faucet	7/29/16 10:17 AM	8/5/2016	1608142-08A	LEAD	<1.0 PPB	15 PPB
047-09A	Classroom 4 Drinking Fountain	7/29/16 10:17 AM	8/5/2016	1608142-09A	LEAD	1 PPB	15 PPB
047-10A	Classroom 3 Sink Faucet	7/29/16 10:25 AM	8/5/2016	1608142-10A	LEAD	<1.0 PPB	15 PPB
047-11A	Classroom 3 Drinking Fountain	7/29/16 10:25 AM	8/5/2016	1608142-11A	LEAD	4 PPB	15 PPB
047-12A	Hall Drinking Fountain 2	7/29/16 10:28 AM	8/5/2016	1608142-12A	LEAD	<1.0 PPB	15 PPB
047-13A	Classroom 2 Sink Faucet	7/29/16 10:30 AM	8/5/2016	1608142-13A	LEAD	2 PPB	15 PPB
047-14A	Classroom 2 Drinking Fountain	7/29/16 10:30 AM	8/5/2016	1608142-14A	LEAD	<1.0 PPB	15 PPB
047-15A	Classroom 1 Sink Faucet	7/29/16 10:35 AM	8/5/2016	1608142-15A	LEAD	<1.0 PPB	15 PPB
047-16A	Classroom 1 Drinking Fountain	7/29/16 10:35 AM	8/6/2016	1608142-16A	LEAD	2 PPB	15 PPB
047-17A	Kitchen Food Prep Sink Faucet	7/29/16 10:10 AM	8/5/2016	1608142-17A	LEAD	2 PPB	15 PPB
047-18A	Cafeteria Drinking Fountain	7/29/16 10:12 AM	8/5/2016	1608142-18A	LEAD	13 PPB	15 PPB
047-19A	Office Sink Faucet	7/29/16 10:55 AM	8/5/2016	1608142-19A	LEAD	6 PPB	15 PPB
047-20A	Classroom 12 Sink Faucet	7/29/16 10:50 AM	8/5/2016	1608142-20A	LEAD	<1.0 PPB	15 PPB
047-21A	Classroom 12 Drinking Fountain	7/29/16 9:50 AM	8/5/2016	1608142-21A	LEAD	4 PPB	15 PPB
047-22A	Classroom 11 Sink Faucet	7/29/16 9:45 AM	8/5/2016	1608142-22A	LEAD	<1.0 PPB	15 PPB
047-23A	Classroom 11 Drinking Fountain	7/29/16 9:45 AM	8/5/2016	1608142-23A	LEAD	3 PPB	15 PPB
047-24A	Hall Drinking Fountain 3	7/29/16 9:10 AM	8/6/2016	1608142-24A	LEAD	3 PPB	15 PPB
047-25A	Hall Drinking Fountain 4	7/29/16 9:10 AM	8/6/2016	1608142-25A	LEAD	2 PPB	15 PPB
047-26A	Faculty WorkClassroom Sink Faucet	7/29/16 9:07 AM	8/5/2016	1608142-26A	LEAD	1 PPB	15 PPB
047-27A	Hall Drinking Fountain 5	7/29/16 9:13 AM	8/5/2016	1608142-27A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Salem Heights Elementary School

047-28A	Classroom 13 Sink Faucet	7/29/16 9:17 AM	8/5/2016	1608142-28A	LEAD	16	PPB	15 PPB
047-29A	Classroom 13 Drinking Fountain	7/29/16 9:17 AM	8/5/2016	1608142-29A	LEAD	5	PPB	15 PPB
047-30A	Classroom 14 Sink Faucet	7/29/16 9:19 AM	8/5/2016	1608142-30A	LEAD	1	PPB	15 PPB
047-31A	Classroom 14 Drinking Fountain	7/29/16 9:19 AM	8/5/2016	1608142-31A	LEAD	4	PPB	15 PPB
047-32A	Music 18 Sink Faucet	7/29/16 9:26 AM	8/5/2016	1608142-32A	LEAD	<1.0	PPB	15 PPB
047-33A	Music 18 Drinking Fountain	7/29/16 9:26 AM	8/5/2016	1608142-33A	LEAD	4	PPB	15 PPB
047-34A	Classroom 18 Sink Faucet	7/29/16 9:23 AM	8/5/2016	1608142-34A	LEAD	<1.0	PPB	15 PPB
047-35A	Classroom 18 Drinking Fountain	7/29/16 9:23 AM	8/5/2016	1608142-35A	LEAD	5	PPB	15 PPB
047-36A	Classroom 16 Sink Faucet	7/29/16 9:30 AM	8/5/2016	1608142-36A	LEAD	<1.0	PPB	15 PPB
047-37A	Classroom 16 Drinking Fountain	7/29/16 9:30 AM	8/5/2016	1608142-37A	LEAD	3	PPB	15 PPB
047-38A	Classroom 17 Sink Faucet	7/29/16 9:38 AM	8/5/2016	1608142-38A	LEAD	<1.0	PPB	15 PPB
047-39A	Classroom 17 Drinking Fountain	7/29/16 9:38 AM	8/5/2016	1608142-39A	LEAD	3	PPB	15 PPB
047-40A	Classroom 20 Sink Faucet	7/29/16 9:41 AM	8/5/2016	1608142-40A	LEAD	<1.0	PPB	15 PPB
047-41A	Classroom 20 Drinking Fountain	7/29/16 9:41 AM	8/5/2016	1608142-41A	LEAD	3	PPB	15 PPB
047-42A	Classroom 23 Sink Faucet	7/29/16 12:19 PM	8/5/2016	1608142-42A	LEAD	3	PPB	15 PPB
047-43A	Classroom 24 Sink Faucet	7/29/16 12:21 PM	8/5/2016	1608142-43A	LEAD	3	PPB	15 PPB
047-45A	Classroom 19 Sink Faucet	7/29/16 9:34 AM	8/5/2016	1608142-44A	LEAD	2	PPB	15 PPB
047-46A	Classroom 19 Drinking Fountain	7/29/16 9:34 AM	8/5/2016	1608142-45A	LEAD	<1.0	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 Flushed (B) Sample Data  
 Salem Heights Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
047-28B Classroom 13 Sink Faucet	7/29/16 9:18 AM	8/31/2016	1608143-27A	LEAD	2 PPB	15 PPB
EPA Action Level for Lead in Schools is 20 PPB						
SKPS Action Level for Lead is 15 PPB						
<b>Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level</b>						

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Salem Heights Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Collected	Container ID	Tested For	Result	Action Level
047-28C Classroom 13 Sink Faucet	10/27/16 5:00 AM	10/28/2016	65870	LEAD	9 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Salem Heights Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
047-18C Cafeteria Drinking Fountain (Replaced)	8/4/17 7:30 AM	8/7/2017	43362	LEAD	3 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Salem Heights Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Collected	Container ID	Tested For	Results		Action Level
047-47A	Basement Room 21 Drinking Fountain	9/1/2017 8:14	9/5/2017	50667	LEAD	11	PPB	15 PPB
047-48A	Basement Storage Sink Faucet	9/1/2017 8:13	9/5/2017	50668	LEAD	1	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

### LEAD & COPPER RULE REPORT

Client Name: TRC - Milwaukie  
4120 SE International Way  
Suite A110  
Milwaukie, OR 97222

Reference Number: **22-04574**

Project: Salem Heights  
Elementary School -  
439409.1000.0012

System Name:  
System ID Number:  
DWP Source Number:  
Multiple Sources:  
Sample Type:  
Sample Purpose: Investigative or Other  
County:

Analyst: tjb  
Date Received: 2/9/2022  
Report Date: 2/16/2022  
Approved By: bj  
Authorized by:

Thanh B Phan  
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
22_08947	2/9/2022	292022-47-47 - Gym Entry Drinking Water Fountain	1030	LEAD	ND	ppb	15	1	200.8	046	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.