

## South Salem High School - 2022 Lead in Drinking Water Sampling Results

<b>Inst. Name:</b>	Salem-Keizer Public Schools
<b>Inst. ID #:</b>	775
<b>School Name:</b>	South Salem High School
<b>Building ID #:</b>	21424200

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Main Office Hallway 102, Staff Faucet	21424200-001SF	2022-06-08	21424200-001SF22A	<1	No
Hallway at Room 134A, Drinking Water Fountain	21424200-002DW	2022-06-08	21424200-002DW22A	<1	No
Hallway at Classroom 111, Drinking Water Fountain	21424200-003DW	2022-06-08	21424200-003DW22A	<1	No
Science Prep 111A, East Staff Faucet	21424200-004SF	2022-06-08	21424200-004SF22A	<1	No
Classroom 128, Classroom Faucet	21424200-005CF	2022-06-08	21424200-005CF22A	<1	No
Classroom 128, Ice Machine	21424200-006IM	2022-06-08	21424200-006IM22A	<1	No
Hallway at Classroom 112, Left Drinking Water Fountain	21424200-007DW	2022-06-08	21424200-007DW22A	<1	No
Hallway at Classroom 112, Right Drinking Water Fountain	21424200-008DW	2022-06-08	21424200-008DW22A	<1	No
Hallway at Classroom 112, Water Bottle Filler	21424200-009WB	2022-06-08	21424200-009WB22A	<1	No
Locker Room, South Portion, Left Drinking Water Fountain	21424200-010DW	2022-06-08	21424200-010DW22A	1	No
Locker Room, South Portion, Right Drinking Water Fountain	21424200-011DW	2022-06-08	21424200-011DW22A	<1	No
Locker Room, North Portion, Drinking Water Fountain	21424200-012DW	2022-08-10	21424200-012DW22A	12.9	No
Main Gym, Southwest Corner, Drinking Water Fountain	21424200-013DW	2022-06-08	21424200-013DW22A	1.4	No
Main Gym, Southeast Corner, Drinking Water Fountain	21424200-014DW	2022-06-08	21424200-014DW22A	<1	No
Locker Room, South Portion, Left Drinking Water Fountain	21424200-015DW	2022-06-08	21424200-015DW22A	<1	No
Locker Room, South Portion, Right Drinking Water Fountain	21424200-016DW	2022-06-08	21424200-016DW22A	<1	No
Locker Room, North Portion, Drinking Water Fountain	21424200-017DW	2022-06-08	21424200-017DW22A	<1	No
Hallway at Classroom 117, Left Drinking Water Fountain	21424200-018DW	2022-06-08	21424200-018DW22A	<1	No
Hallway at Classroom 117, Right Drinking Water Fountain	21424200-019DW	2022-06-08	21424200-019DW22A	<1	No
Hallway at Classroom 117, Water Bottle Filler	21424200-020WB	2022-06-08	21424200-020WB22A	<1	No
Room adjacent Team Room 119, Countertop Staff Faucet	21424200-021SF	2022-06-08	21424200-021SF22A	<1	No
Locker Room adjacent Team Room 119, Staff Faucet	21424200-022SF	2022-06-08	21424200-022SF22A	5.5	No
Locker Room adjacent Team Room 119, Ice Machine	21424200-023IM	2022-06-08	21424200-023IM22A	<1	No
Locker Room 119, South Portion, Left Drinking Water Fountain	21424200-024DW	2022-08-10	21424200-024DW22A	3.8	No
Locker Room 119, South Portion, Right Drinking Water Fountain	21424200-025DW	2022-08-10	21424200-025DW22A	3.6	No

m Room 119, North Portion, Drinking Water Foun	21424200-026DW	2022-06-08	21424200-026DW22A	2.4	No
Student Store, Kitchen Faucet	21424200-027KF	2022-06-08	21424200-027KF22A	<1	No
ffee Stand at Upper Commons, Kitchen Faucet (C	21424200-028KF	2022-06-08	21424200-028KF22A	5.4	No
Storage Office 138, Staff Faucet	21424200-029SF	2022-06-08	21424200-029SF22A	<1	No
Library Workroom 140B, Staff Faucet	21424200-030SF	2022-06-08	21424200-030SF22A	3.7	No
Hallway at Classroom 170, Drinking Water Fountai	21424200-031DW	2022-06-08	21424200-031DW22A	<1	No
Room 188A, Staff Faucet	21424200-032SF	2022-06-08	21424200-032SF22A	<1	No
Classroom 188, Classroom Faucet	21424200-033CF	2022-06-08	21424200-033CF22A	<1	No
Classroom 189, North Edge, Left Classroom Faucet	21424200-034CF	2022-06-08	21424200-034CF22A	<1	No
Classroom 189, North Edge, Center Classroom Faucet	21424200-035CF	2022-06-08	21424200-035CF22A	<1	No
Classroom 189, North Edge, Right Classroom Faucet	21424200-036CF	2022-06-08	21424200-036CF22A	<1	No
Classroom 189, East Island Classroom Faucet	21424200-037CF	2022-06-08	21424200-037CF22A	<1	No
Classroom 189, South Edge, Left Classroom Faucet	21424200-038CF	2022-06-08	21424200-038CF22A	<1	No
Classroom 189, South Edge, Center Classroom Faucet	21424200-039CF	2022-06-08	21424200-039CF22A	<1	No
Classroom 189, South Edge, Right Classroom Faucet	21424200-040CF	2022-06-08	21424200-040CF22A	<1	No
Cafe across from Auditorium 57, Left Kitchen Faucet	21424200-041KF	2022-06-08	21424200-041KF22A	<1	No
Cafe across from Auditorium 57, Right Kitchen Faucet	21424200-042KF	2022-06-08	21424200-042KF22A	<1	No
Classroom 191, Ice Machine	21424200-043IM	2022-06-08	21424200-043IM22A	<1	No
Classroom 191, South Edge, Leftmost Classroom Faucet	21424200-044CF	2022-06-08	21424200-044CF22A	<1	No
Classroom 191, South Edge, Left of Center Classroom Faucet	21424200-045CF	2022-06-08	21424200-045CF22A	<1	No
Classroom 191, South Edge, Center Classroom Faucet	21424200-046CF	2022-06-08	21424200-046CF22A	<1	No
Classroom 191, South Edge, Right of Center Classroom Faucet	21424200-047CF	2022-06-08	21424200-047CF22A	<1	No
Classroom 191, South Edge, Rightmost Classroom Faucet	21424200-048CF	2022-06-08	21424200-048CF22A	<1	No
North Portion, Dishwashing Classroom Faucet adjacent	21424200-049CF	2022-06-08	21424200-049CF22A	<1	No
Classroom 191, North Portion, Left Dual Classroom Faucet	21424200-050CF	2022-06-08	21424200-050CF22A	<1	No
Classroom 191, North Portion, Right Dual Classroom Faucet	21424200-051CF	2022-06-08	21424200-051CF22A	<1	No
Hallway at Auditorium 57, Left Drinking Water Fountain	21424200-052DW	2022-06-08	21424200-052DW22A	<1	No
Hallway at Auditorium 57, Right Drinking Water Fountain	21424200-053DW	2022-06-08	21424200-053DW22A	<1	No
Hallway at Auditorium 57, Water Bottle Filler	21424200-054WB	2022-06-08	21424200-054WB22A	<1	No
Hallway at Classroom 154, Drinking Water Fountain	21424200-055DW	2022-06-08	21424200-055DW22A	1.5	No
Staff Room 201, Staff Faucet	21424200-056SF	2022-06-08	21424200-056SF22A	<1	No
Hallway at Classroom 203, Drinking Water Fountain	21424200-057DW	2022-08-10	21424200-057DW22A	1.5	No
Hallway at Classroom 209, Drinking Water Fountain	21424200-058DW			Not Working	
Hallway at Classroom 211, Left Drinking Water Fountain	21424200-059DW	2022-06-08	21424200-059DW22A	<1	No
Hallway at Classroom 211, Right Drinking Water Fountain	21424200-060DW	2022-06-08	21424200-060DW22A	<1	No
Hallway at Classroom 211, Water Bottle Filler	21424200-061WB	2022-06-08	21424200-061WB22A	<1	No
Cony Gym 222 (Wrestling Room), Drinking Water Fountain	21424200-062DW	2022-06-08	21424200-062DW22A	<1	No
East Balcony Gym 218, Drinking Water Fountain	21424200-063DW	2022-06-08	21424200-063DW22A	2.3	No

Hallway at Classroom 214, Left Drinking Water Fountain	21424200-064DW	2022-06-08	21424200-064DW22A	<1	No
Hallway at Classroom 214, Right Drinking Water Fountain	21424200-065DW	2022-06-08	21424200-065DW22A	<1	No
Hallway at Classroom 214, Water Bottle Filler	21424200-066WB	2022-06-08	21424200-066WB22A	<1	No
Upper Library Workroom 234, Staff Faucet	21424200-067SF	2022-06-08	21424200-067SF22A	12.8	No
Hallway at Classroom 253, Drinking Water Fountain	21424200-068DW	2022-06-08	21424200-068DW22A	<1	No
Classroom 251, Classroom Faucet	21424200-069CF	2022-06-08	21424200-069CF22A	1.8	No
Classroom 250, Classroom Faucet	21424200-070CF	2022-06-08	21424200-070CF22A	10.4	No
Classroom 239, Classroom Faucet	21424200-071CF	2022-06-08	21424200-071CF22A	9	No
Classroom 240, Classroom Faucet	21424200-072CF	2022-06-08	21424200-072CF22A	5.6	No
Staff Room 238B, Staff Faucet	21424200-073SF	2022-06-08	21424200-073SF22A	<1	No
Hallway at Classroom 293, Left Drinking Water Fountain	21424200-074DW			Not Working	
Hallway at Classroom 293, Right Drinking Water Fountain	21424200-075DW			Not Working	
Hallway at Classroom 293, Water Bottle Filler	21424200-076WB			Not Working	
Hallway at Classroom 244, Drinking Water Fountain	21424200-077DW	2022-06-08	21424200-077DW22A	1	No
Classroom 244, Classroom Faucet	21424200-078CF	2022-06-08	21424200-078CF22A	1	No
Classroom 243, Classroom Faucet	21424200-079CF	2022-06-08	21424200-079CF22A	3.5	No
Classroom 242, Classroom Faucet	21424200-080CF	2022-06-08	21424200-080CF22A	6.3	No
Classroom 241, Classroom Faucet	21424200-081CF	2022-06-08	21424200-081CF22A	3	No
North Cafeteria, Drinking Water Fountain	21424200-082DW	2022-06-08	21424200-082DW22A	<1	No
Kitchen 22, North Dishwashing Area, Kitchen Faucet	21424200-083KF	2022-06-08	21424200-083KF22A	<1	No
Kitchen 22, Center at North Wall, Kitchen Faucet	21424200-084KF	2022-06-08	21424200-084KF22A	<1	No
Kitchen 22, Center at East Wall, Kitchen Faucet	21424200-085KF	2022-06-08	21424200-085KF22A	1.3	No
Kitchen 22, Center Island, Kitchen Faucet	21424200-086KF	2022-06-08	21424200-086KF22A	11.1	No
Kitchen 22, Ice Machine	21424200-087IM	2022-06-08	21424200-087IM22A	<1	No
Lower Commons, Left Drinking Water Fountain	21424200-088DW	2022-06-08	21424200-088DW22A	<1	No
Lower Commons, Right Drinking Water Fountain	21424200-089DW	2022-06-08	21424200-089DW22A	<1	No
Concessions (Exterior Access), Kitchen Faucet	21424200-090KF	2022-08-10	21424200-090KF22B	5.3	No
Entryway at Auxiliary Gym, Left Drinking Water Fountain	21424200-091DW	2022-06-08	21424200-091DW22A	<1	No
Entryway at Auxiliary Gym, Right Drinking Water Fountain	21424200-092DW	2022-06-08	21424200-092DW22A	<1	No
Entryway at Auxiliary Gym, Water Bottle Filler	21424200-093WB	2022-06-08	21424200-093WB22A	<1	No
Light Room, Southeast Portion, Drinking Water Fountain	21424200-094DW	2022-06-08	21424200-094DW22A	<1	No
Room 58 (Access from Ground Hallway at Cafeteria, go up stairs then behind boilers), Custodial Office	21424200-095SF	2022-06-08	21424200-095SF22A	2.5	No
Room 58 (Access from Ground Hallway at Cafeteria, go down stairs then behind boilers), Custodial Office	21424200-096OT	2022-06-08	21424200-096OT22A	3.4	No
Ground Floor Hallway adjacent Custodial Office), Custodial Office	21424200-097OT	2022-06-08	21424200-097OT22A	<1	No
Classroom 18, Drinking Water Fountain	21424200-098DW	2022-06-08	21424200-098DW22A	1.8	No
Room 12C off Classroom 12, Staff Faucet	21424200-099SF	2022-06-08	21424200-099SF22A	2.7	No
Classroom 12, Classroom Faucet	21424200-100CF	2022-06-08	21424200-100CF22A	<1	No
Hallway at Classroom 52, Left Drinking Water Fountain	21424200-101DW	2022-06-08	21424200-101DW22A	<1	No

Way at Classroom 52, Right Drinking Water Foun	21424200-102DW	2022-06-08	21424200-102DW22A	<1	No
Hallway at Classroom 52, Water Bottle Filler	21424200-103WB	2022-06-08	21424200-103WB22A	<1	No
Makeup Room 60, Classroom Faucet	21424200-104CF	2022-06-08	21424200-104CF22A	<1	No
Classroom 68, Left Classroom Faucet	21424200-105CF	2022-06-08	21424200-105CF22A	<1	No
Classroom 68, Drinking Water Fountain	21424200-106DW	2022-06-08	21424200-106DW22A	<1	No
Classroom 68, Right Classroom Faucet	21424200-107CF	2022-06-08	21424200-107CF22A	<1	No
Classroom 70, Classroom Faucet	21424200-108CF	2022-06-08	21424200-108CF22A	<1	No
Classroom 70, Drinking Water Fountain	21424200-109DW	2022-06-08	21424200-109DW22A	<1	No
Classroom 72, Classroom Faucet	21424200-110CF	2022-06-08	21424200-110CF22A	<1	No
Classroom 72, Drinking Water Fountain	21424200-111DW	2022-06-08	21424200-111DW22A	<1	No