

## Straub Environmental Learning Center - 2022 Lead in Drinking Water Sampling Results

<b>Inst. Name:</b>	Salem-Keizer Public Schools
<b>Inst. ID #:</b>	773
<b>School Name:</b>	Straub Environmental Learning Center
<b>Building ID #:</b>	21424002

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Main Entrance Room, Left Drinking Water Fountain	21424002-001DW	2022-05-20	21424002-001DW22A	2.1	No
Main Entrance Room, Right Drinking Water Fountain	21424002-002DW	2022-05-20	21424002-002DW22A	11.9	No
Storage Room through Office, Staff Faucet	21424002-003SF	2022-05-20	21424002-003SF22A	3.3	No
Classroom Front Teacher Sink, Classroom Faucet	21424002-004CF	2022-05-20	21424002-004CF22A	3.5	No