

Valley Inquiry Charter School - 2021 Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	N/A
School Name:	Valley Inquiry Charter School
Building ID #:	21426000

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Staff Lounge	21426000-001-SF	2021-06-17	6172021-21426000-001-SF	<1	No
Health Room	21426000-002-NS	2021-06-17	6172021-21426000-002-NS	3.85	No
Main Office	21426000-003-DW	2021-06-17	6172021-21426000-003-DW	<1	No
Main Office	21426000-004-WB	2021-06-17	6172021-21426000-004-WB	<1	No
Kitchen	21426000-005-KF	2021-06-17	6172021-21426000-005-KF	3.68	No
Kitchen	21426000-006-KF	2021-06-17	6172021-21426000-006-KF	<1	No
Kitchen	21426000-007-KF	2021-06-17	6172021-21426000-007-KF	<1	No
Room 1	21426000-008-DW	2021-06-17	6172021-21426000-008-DW	7.46	No
Room 1	21426000-009-CF	2021-06-17	6172021-21426000-009-CF	<1	No
Room 2	21426000-010-DW	2021-06-17	6172021-21426000-010-DW	<1	No
Room 2	21426000-011-CF	2021-06-17	6172021-21426000-011-CF	13.9	No
Room 3	21426000-012-DW	2021-06-17	6172021-21426000-012-DW	5.88	No
Room 3	21426000-013-CF	2021-06-17	6172021-21426000-013-CF	11.4	No
Room 4	21426000-014-DW	2021-06-17	6172021-21426000-014-DW	2.93	No
Room 4	21426000-015-CF	2021-06-17	6172021-21426000-015-CF	7.1	No
Room 5	21426000-016-DW	2021-06-17	6172021-21426000-016-DW	<1	No
Room 5	21426000-017-CF	2021-06-17	6172021-21426000-017-CF	7.66	No
Room 6 - Library	21426000-018-DW	2021-06-17	6172021-21426000-018-DW	2.48	No
Room 6 - Library	21426000-019-CF	2021-06-17	6172021-21426000-019-CF	4.42	No
Room 7	21426000-020-DW	2021-06-17	6172021-21426000-020-DW	1.19	No
Room 7	21426000-021-CF	2021-06-17	6172021-21426000-021-CF	5.1	No