

### Yoshikai Elementary School Childcare Fixtures - Drinking Water Sampling Results

<b>Inst. Name:</b>	Salem-Keizer Public Schools
<b>Inst. ID #:</b>	764
<b>School Name:</b>	Yoshikai Childcare Facility
<b>Building ID #:</b>	21423000

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Cafeteria Multi-use, Restroom, Left Drinking Water Fountain	21423000-001DW	2022-05-25	21423000-001DW22A	<1	No
Cafeteria Multi-Use Room, Restroom, Right Drinking Water Fountain	21423000-002DW	2022-05-25	21423000-002DW22A	<1	No
Cafeteria Multi-Use Room, Staff Faucet	21423000-003SF	2022-05-25	21423000-003SF22A	2	No
Gym, Drinking Water Fountain	21423000-004DW	2022-05-25	21423000-004DW22A	<1	No